



This certificate is not valid if the serial number has been defaced or altered

350020

ICR18

ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 - Requirements for Electrical Installations

Original (to the person ordering the work)

PART 9 : SCHEDULE OF ITEMS INSPECTED

- 8.13 Wiring systems and cable installation methods / practices appropriate to the type and nature of installation and external influences: (✓)
- 8.14 Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage: (✓)
- 8.15 Cables installed in walls / partitions, installed in prescribed zones: (✓)
- 8.16 Provision of additional protection by RCDs having rated residual operating current (I_{Δn}) not exceeding 30 mA:
 - a) For all socket-outlets with a rated current not exceeding 32 A or less, unless exempt (✓)
 - b) For supplies to mobile equipment with a current rating not exceeding 32 A for use outdoors (✓)
 - c) For cables concealed in walls / partitions at a depth of less than 50 mm (✓)
 - d) For cables concealed in walls / partitions containing metal parts regardless of depth (✓)
 - e) For circuits supplying luminaires within domestic (household) premises only (✓)
- 8.17 Provision of fire barriers, sealing arrangements so as to minimise the spread of fire: (✓)
- 8.18 Band II cables segregated / separated from Band I cables: (✓)
- 8.19 Cables segregated / separated from non-electrical services: (✓)
- 8.20 Termination of cables at enclosures:
 - a) Connections under no undue strain (✓)
 - b) No basic insulation of a conductor visible outside enclosure (✓)
 - c) Connections of live conductors adequately enclosed (✓)
 - d) Adequately connected at point of entry to enclosure (✓)
- 8.21 Suitability of circuit accessories for external influences: (✓)
- 8.22 Circuit accessories not damaged during erection: (✓)
- 8.23 Single-pole devices for switching or protection in line conductors only: (✓)

- 8.24 Adequacy of connections, including cpcs, within accessories and at fixed and stationary equipment: (✓)
- 9. Isolation and switching**
- 9.1 Isolators:
 - a) Presence and location of appropriate devices (✓)
 - b) Capable of being secured in the OFF position (✓)
 - c) Correct operation verified (functional check) (✓)
 - d) The installation, circuit or part thereof that will be isolated is clearly identified by location and / or durable marking (✓)
 - e) Warning notice posted in situations where live parts cannot be isolated by the operation of a single device (✓)
- 9.2 Switching off for mechanical maintenance:
 - a) Presence of appropriate devices (✓)
 - b) Acceptable location (local or remote) (✓)
 - c) Capable of being secured in the OFF position (✓)
 - d) Correct operation verified (functional check) (✓)
 - e) The installation, circuit or part thereof to be disconnected clearly identified by location and / or durable marking (✓)
- 9.3 Emergency switching / stopping:
 - a) Presence of appropriate devices (✓)
 - b) Readily accessible for operation where danger might occur (✓)
 - c) Correct operation verified (functional check) (✓)
 - d) The installation, circuit or part thereof to be disconnected clearly identified by location and / or durable marking (✓)
 - e) Firefighter's switches present, where required: (✓)
- 9.4 Functional switching:
 - a) Presence of appropriate devices (✓)
 - b) Correct operation verified (functional check) (✓)

- 10. Current-using equipment (permanently connected)**
- 10.1 Suitability of equipment in terms of IP and fire ratings: (✓)
- 10.2 Enclosure not damaged / deteriorated during installation so as to impair safety: (✓)
- 10.3 Suitability for the environment and external influences: (✓)
- 10.4 Security of fixing: (✓)
- 10.5 Cable entry holes in ceilings above luminaires, sized or sealed so as to restrict the spread of fire: (✓)
- 10.6 Recessed luminaires (downlighters):
 - a) Correct type of lamps fitted (✓)
 - b) Installed to minimise build-up of heat (✓)
- 10.7 Provision of undervoltage protection, where specified: (✓)
- 10.8 Provision of overload protection, where specified: (✓)
- 10.9 Adequacy of working space / accessibility to equipment: (✓)

- 11. Special installations or locations**
- List below any special installations or locations which are part of the installation to be verified, and confirm that the additional requirements given in the respective section of Part 7 are fulfilled:
- Photovoltaic System (✓)
- Shower Rooms (✓)
- ()
- ()
- ()
- Details must be appended on a separate numbered page (see PART 10 below)*

SCHEDULE OF ITEMS INSPECTED BY
 Name (capital): SCOTT MARTIN
 Signature: Date: 30/09/2021

PART 10 : SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspections	Schedule of Circuit Details and Test Results for the installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 11 above)	Continuation sheets
Page No(s): (4 & 5)	Page No(s): (6)	Page No(s): ()	Page No(s): ()	Page No(s): (7,8,10,12,14,18,20)

The pages identified are an essential part of this certificate.