

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

REGISTERED BUSINESS DETAILS

Reg No: **20688**

Company: **C CARROTHERS & SON**

Address: **LONGCREST KIRKBRIDE**
WIGTON CUMB

Postcode: **CA7 5BA**

Tel: **016973 51288**

INSPECTION/INSTALLATION ADDRESS

Name & Title:

Address: **60 SHEFFIELD STREET**
CARLISLE

Postcode: **CA2 5DT** Tel:

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title: **G.M. & S.M. MARRS**

Address: **FELTON FOLD**
WIGTON
CUMB

Postcode: **CA7 8AD** Tel: **016973 42451**

Number of appliances tested: **3**

APPLIANCE DETAILS							FLUE TESTS				INSPECTION DETAILS						
	Location	Make and Model	Type	Flue Type OF/RS/FL	Operating pressure in mbar or heat input kW/h or Btu/h	Safety device(s) correct operation Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet flue flow test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance Yes/No/NA	Inspected Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No
1	LIVING	RAK/BERMUDA 57/4M	BROKER	OF	10.7	YES	PASS	PASS	—	—	YES	PASS	YES	YES	YES	YES	YES
2	LIVING	BAKI 11 LFESSURE	FIRE	OF	12.3	YES	PASS	PASS	—	—	YES	PASS	YES	YES	YES	YES	YES
3	KITCHEN	STOVES, PANACHE	COOKER	FL	19.8	NA	NA	NA	—	—	NA	NA	YES	YES	YES	NO	YES
4																	
5																	

Gas Installation Pipework: Satisfactory Visual Inspection: Yes ☒ No ☐ Emergency Control Accessible: Yes ☒ No ☐ Satisfactory Gas Tightness Test: Yes ☒ No ☐ Equipotential Bonding Satisfactory: Yes ☒ No ☐

GIVE DETAILS OF ANY FAULTS				RECTIFICATION WORK CARRIED OUT				WARNING NOTICE ISSUED Yes/No/NA	WARNING TAG or STICKER FIXED Yes/No/NA
1									
2									
3									
4									
5									

Audible CO Alarms: Approved CO Alarms Fitted: Yes ☒ No ☐ N/A ☐ Are CO Alarms in Date: Yes ☒ No ☐ N/A ☐ Testing of CO Alarms Satisfactory: Yes ☒ No ☐ N/A ☐ Smoke Alarms Fitted: Yes ☒ No ☐ N/A ☐

OTHER COMMENTS OR OBSERVATIONS

NEXT GAS SAFETY CHECK DUE BEFORE:

14/12/21

ISSUED BY (GAS ENGINEER)

Print Name: **A CARROTHERS** Signed: **A Carroth**

Licence No: **4564849** Issue Date: **14-2-2020**

RECEIVED BY

Received By: **G.M. MARRS** (Delete as applicable) Tenant/Agent/Landlord/Home Owner No one present at time of visit ☐

Signed: **G.M. MARRS** Print Name: