

DOMESTIC ELECTRICAL INSTALLATION PERIODIC INSPECTION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX.

A DETAILS OF THE CLIENT Client / Address: <i>MRS MIDDLETON</i> <i>3 ST MARKS CLOSE</i> <i>NYMESNOLD LERBN.</i>	B ADDRESS AND DETAILS OF THE INSTALLATION Address: <i>21 BROWNING RD</i> <i>LANGISBOROUGH</i> Estimated age of the electrical installation: <i>30</i> years Evidence of alterations or additions: <i>YES</i> If yes, estimated age: <i>5</i> years Date of previous inspection: <i>24/1/06</i> Electrical Installation Certificate number or previous Periodic Inspection Report number: <i>BR21/DCM2</i> Records of installation available: <i>YES</i> Records held by: <i>CLIENT</i>
C PURPOSE OF THE REPORT † (see note below) Purpose for which this report is required: <i>PERIODIC INSPECTION</i>	D EXTENT OF THE INSTALLATION AND LIMITATIONS OF THE INSPECTION AND TESTING ‡ (see note below) Extent of the electrical installation covered by this report: <i>ALL MAINS</i> Agreed limitations (including the reasons), if any, on the inspection and testing:
E PARTICULARS OF THE APPROVED CONTRACTOR Trading Title: <i>JA ELECTRICAL CONTRACTING LTD</i> Address: <i>BRUSS CLOSE</i> <i>QUAD</i> Postcode: <i>LE25 5Y</i> NICEIC Enrolment No (Essential information): <i>027209</i> Branch No: (if applicable)	F DECLARATION I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above (see B), having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (see G) and the attached schedules (see K and L), provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations of the inspection and testing (see D). I/We further declare that in my/our judgement, the said installation was overall in <i>satisfactory</i> condition (see H) at the time the inspection was carried out, and that it should be further inspected as recommended (see I). * (Insert 'a satisfactory' or 'an unsatisfactory', as appropriate) INSPECTION, TESTING AND ASSESSMENT BY: Signature: <i>[Signature]</i> Name: <i>Paul</i> (CAPITALS) Position: <i>Director</i> Date: <i>28/2/2011</i> REPORT REVIEWED AND CONFIRMED BY: * See note below Signature: <i>[Signature]</i> Name: <i>Paul</i> (CAPITALS) (Registered Qualified Supervisor for the Approved Contractor at E) Date: <i>28/2/11</i>

† This Domestic Periodic Inspection Report must be used only for reporting on the condition of an existing installation.

‡ The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected.

* This Domestic Periodic Inspection Report should be reviewed and confirmed by the registered Qualified Supervisor of the Approved Contractor responsible for issuing it.

SCHEDULES

M CIRCUIT DETAILS											N TEST RESULTS																
Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa		Max. disconnection time permitted by BS 7671 (s)	Overcurrent protective devices				RCD Operating current I _{Δn} (mA)	Maximum Z _s permitted by BS 7671 (Ω)	Circuit impedances (Ω)					Insulation resistance				Polarity (✓)	Maximum measured earth fault loop impedance, Z _s (Ω)	RCD operating times t		
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type No	Rating (A)	Short-Circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)	Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)	at I _{Δn} (ms)			at 5 I _{Δn} (if applicable) (ms)		
														r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)										R ₁ + R ₂	R ₂
1	COOKER	A C	1	6	2.5	4	600	48	B	32	6	1.5		0.1	/	/	200	200	200	/	0.22						
2	DOWNSTAIRS LIGHTING	A C	3	1	1.5		"	B	6	6	6/8		0.5	/	/	"	"	"	/	0.65							
3																											
4																											
5																											
6																											
7	SHOWER	A C	1	6	2.5	4	600	48	B	32	6	30	1.5	0.2	/	/	"	"	"	/	0.32	18	11				
8	RING MAIN	A C	4	2.5	1.5	4	"	"	32	6	30	1.5	0.5	0.5	0.8	0.3	/	/	"	"	"	/	0.56	"	"		
9	SILET NR COOKER	A C	1	2.5	1.5	4	"	"	16	6	30	2.3	0.1	/	/	"	"	"	/	0.23	"	"					
10	SILET NM/2154	A C	1	2.5	1.5	4	"	"	16	6	30	2.3	0.1	/	/	"	"	"	/	0.26	"	"					
11	LIGHTING W/STAIRS	A C	6	10	10	4	"	"	4	4	30	6/13	0.7	/	/	"	"	"	/	0.85	"	"					
12																											
13																											
14																											
15																											
16																											
17																											
18																											
19																											
20																											
Location of consumer unit(s)		UNDERSTAIRS										Designation of consumer unit(s)		Prospective fault current at consumer unit(s)		1.55		kA									

TEST INSTRUMENTS		Test instruments (serial numbers) used				
Multi-functional	90830	Insulation resistance	Continuity	Earth electrode resistance	Earth fault loop impedance	RCD

† All boxes must be completed. '✓' indicates that an inspection or a test was carried out and that the result was satisfactory. 'X' indicates that an inspection or a test was carried out and that the result was unsatisfactory.
 ‡ 'N/A' indicates that an inspection or a test was not applicable to the particular installation. 'LIM' indicates that, exceptionally, a limitation agreed with the person ordering the work (as recorded in Section D) prevented the inspection or test being carried out.

G OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

Referring to the attached schedules of inspection and test results, and subject to the limitations at D:

There are no items adversely affecting electrical safety.
or

The following observations and recommendations are made.

Item No

Code[†]

1

H SUMMARY OF THE INSPECTION

General condition of the installation:

SATISFACTORY

Note: If necessary, continue on additional page(s), which must be identified by the Domestic Periodic Inspection Report serial number and page number(s).

Date(s) of the inspection:

Overall assessment
of the installation:

(Entry should read either 'Satisfactory' or 'Unsatisfactory')

I NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than:

5 Years

(Enter interval in terms of years or months, as appropriate)

provided that any items at G which have been attributed a Recommendation Code 1 (*requires urgent attention*) and Code 2 (*requires improvement*) are remedied without delay and as soon as possible respectively. Items which have been attributed a Recommendation Code 3 should be actioned as soon as practicable (see G).

Note: If necessary, continue on additional page(s), which must be identified by the Domestic Periodic Inspection Report serial number and page number(s).

† Where observations are made, the inspector will have entered one of the following codes against each observation to indicate the action (if any) recommended:-

1. 'requires urgent attention' or
2. 'requires improvement' or
3. 'requires further investigation' or
4. does not comply with BS 7671: (as amended)'

Please see the reverse of this page for guidance regarding the recommendations.

Urgent remedial work recommended for Items:

Corrective action(s) recommended for Items:

Please see the 'Notes for Recipients' on the reverse of this page.

Page 2 of 2

DOMESTIC ELECTRICAL INSTALLATION PERIODIC INSPECTION REPORT (FOR A SINGLE DWELLING)

J SUPPLY CHARACTERISTICS, EARTHING AND BONDING ARRANGEMENTS

Enter details, as appropriate

Supply Characteristics	No. and type of live conductors (✓)	System Type(s) (✓)	Characteristics of Primary Supply Overcurrent Protective Device(s)	Main Switch or Circuit-Breaker	Means of Earthing	Earthing and Protective Bonding Conductors
Nominal voltage: $U^{(1)}$ <u>230</u> V	1-phase (2wire) ✓	TN-S	BS(EN) <u>UNKNOWN</u>	Type: BS(EN) <u>9473</u>	Distributor's facility: ✓	Earthing conductor
Nominal voltage: $U_o^{(2)}$ <u>230</u> V	1-phase (3wire)	TN-CS ✓	Type	Voltage rating <u>400</u> V	Installation earth electrode:	Conductor material <u>COPPER</u>
Nominal frequency, $f^{(1)}$ <u>50</u> Hz	3-phase (3wire)	TT	Rated current	No of Poles <u>2</u>	Type: (eg rod(s), tape etc)	Conductor csa <u>16</u> mm ²
Prospective fault current, $I_{pf}^{(2)}$ <u>1.53</u> kA	3-phase (4wire)		A	Supply conductors material <u>COPPER</u>	Electrode resistance, R_A : (Ω)	Main protective bonding conductors
External earth fault loop impedance, $Z_e^{(3)}$ <u>0.15</u> Ω	Other (please state)		Short-circuit capacity	RCD operating current, $I_{\Delta n}$ <u>100</u> mA	Location:	Conductor material <u>COPPER</u>
Notes:				RCD operating time (at $I_{\Delta n}$) <u>25</u> ms	Method of measurement:	Conductor csa <u>10</u> mm ²
(1) by enquiry						Continuity check ✓ (✓)
(2) by enquiry or by measurement						Continuity check ✓ (✓)
(3) by measurement						

* (applicable only where an RCD is used as a main circuit-breaker)

K SCHEDULE OF ITEMS INSPECTED

† See note below

Additional protection

Protective measures against electric shock

Basic and fault protection

Extra low voltage

Double or reinforced insulation

SELV

Double or reinforced insulation

Basic protection

Insulation of live parts

Barriers or enclosures

Fault protection

Automatic disconnection of supply

Presence of earthing conductor

Presence of circuit protective conductors

Presence of main protective bonding conductors

Choice and setting of protective devices (for fault protection and/or overcurrent)

Electrical separation

For one item of current-using equipment

Prevention of mutual detrimental influence

Proximity of non-electrical services and other influences

Segregation of Band I and Band II circuits or Band II insulation used

Segregation of safety circuits

Identification

Presence of diagrams, instructions, circuit charts and similar information

Presence of danger notices

Presence of other warning notices, including presence of mixed wiring colours

Labelling of protective devices, switches and terminals

Identification of conductors

Cables and conductors

Selection of conductors for current carrying capacity and voltage drop

Erection methods

Cables and conductors (cont)

Routing of cables in prescribed zones

Cables incorporating earthed armour or sheath or run in an earthed wiring system, or otherwise protected against nails, screws and the like

Additional protection by 30mA RCD (where required, in premises not under the supervision of skilled or instructed persons)

Connection of conductors

Presence of fire barriers, suitable seals and protection against thermal effects

General

Presence and correct location of appropriate devices for isolation and switching

Adequacy of access to switchgear and other equipment

Particular protective measures for special installations and locations

Connection of single-pole devices for protection or switching in line conductors only

Correct connection of accessories and equipment

Selection of equipment and protective measures appropriate to external influences

Selection of appropriate functional switching devices

L SCHEDULE OF ITEMS TESTED

External earth fault loop impedance, Z_e

Installation earth electrode resistance, R_A

Continuity of protective conductors

Continuity of ring final circuit conductors

Insulation resistance between live conductors

Insulation resistance between live conductors and earth

Polarity

Earth fault loop impedance, Z_s

Verification of phase sequence

Operation of residual current device(s)

Functional testing of assemblies

Verification of voltage drop

† See note below

† All boxes must be completed. '✓' indicates that an inspection or a test was carried out and that the result was satisfactory. 'X' indicates that an inspection or a test was carried out and that the result was unsatisfactory. 'N/A' indicates that an inspection or a test was not applicable to the particular installation. 'LIM' indicates that, exceptionally, a limitation agreed with the person ordering the work (as recorded in Section D) prevented the inspection or test being carried out.