

# LANDLORD/HOME OWNER GAS SAFETY RECORD

This inspection is for gas safety purposes only in accordance with the current edition of the Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has not been carried out.

GAS INSTALLER: (Trading Title)			
Name:	DAVID PALMER	Gas Safe Register No:	142702
Address:	4A EISTEDDFOD WALK	Gas Installer Ref. No :	556037
	NEWPORT	Date of Issue:	16/9/2013
Post code:	NP19 9EU	Time of Issue:	11.00
Tel:	07767874138	Issued by: (print name)	D PALMER

TENANT/HOME OWNER DETAILS	
Tenant/Home Owner* Name:	MR. T. LAVENDER
Property Address:	7 CONSTANCE ST NEWPORT
Post Code	NP19 70B. Tel:
Tenant/Home Owner* present during inspection	YES/NO <input checked="" type="checkbox"/>

LANDLORD/AGENT DETAILS (if applicable)	
Landlord/Agent* Name:	
Address:	
Post Code	Tel:
Landlord/Agent* present during inspection	YES/NO

APPLIANCE DETAILS					INSPECTION DETAILS				FLUE TEST				RESULTS		
LOCATION	MAKE	MODEL	TYPE	Flue Type e.g. CF or RS	Operating Pressure Mbar	Heat Input Kw	Safety Device Correct Operation Yes/No	Ventilation Adequate Yes/No	Flue Flow Test Pass/Fail	Spillage Test Pass/Fail	Termination Satisfactory Yes/No	Visual Condition Pass/Fail	Appliance Safe To Use Yes/No	Landlord's Appliance Yes/No	Inspected Yes/No
1 KITCHEN	VALLIENT	ECOTEC	Combi.	RS	12.7mb	28 kw.	YES	YES	PASS	PASS	YES	PASS	YES	YES	YES
2 KITCHEN	NEWWOOD	HONG	COOKER	N/A	20mb	NA	YES	N/A	N/A	N/A	N/A	PASS	YES	YES	YES
3															
4															
5															

DETAILS OF ANY FAULTS		REMEDIAL ACTION TAKEN		LABEL & WARNING NOTICE ISSUED	
1				YES	NO
2					
3					
4					
5					

GAS INSTALLATION: Tightness Test PASS  FAIL

NEXT GAS SAFETY CHECK DUE WITHIN 12 MONTHS

This Safety Record is issued by Gas Installer: (SIGNED)	D Palmer	Date:	16/9/2013	Number of appliances tested	2
Received on behalf of Landlord/Home Owner: (SIGNED)		Tenant/Landlord/Agent/Home Owner*			