

Contractor's Reference Number

CRN/

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Issued in accordance with British Standard 7671 – Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX.

A. DETAILS OF THE CLIENT

Client: Elizabeth Hunter

Address: 34 Hillside Avenue
Plymouth
Devon

Postcode: PL4 6PS

B. PURPOSE OF THE REPORT

Purpose for which this report is required: Landlord Report

Date(s) on which inspection and testing were carried out: 01/10/2018 -- 01/10/2018

C. DETAILS OF THE INSTALLATION

Occupier: Elizabeth Hunter

Address: 34 Hillside Avenue
Plymouth
Devon

Postcode: PL4 6PS

Estimated age of the electrical installation: 25 years

Evidence of alterations or additions: yes no

If yes, estimated age: 5 years

Date of previous inspection: Unknown

Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: No records available

Records of installation available: no yes

Records held by: Unknown

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:
Fixed wiring only

Agreed limitations including the reasons, if any, on the inspection and testing:
None

Agreed with:

Operational limitations including the reasons (see page No.)
None

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):

Summary of the condition of the installation continued on additional pages? No Yes Specify page No(s):

Overall assessment of the installation: **SATISFACTORY /**

* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

Original (To the person ordering the work)

Check your certificate is genuine, go to www.checkmyniceicert.com <http://www.checkmyniceicert.com> and put in the certificate number

NOTES FOR RECIPIENT

THIS DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE REFERENCE

The purpose of periodic inspection is to determine, so far as is reasonably practicable, whether an electrical installation is in a satisfactory condition for continued service (see Section E and G). This report provides an assessment of the condition of the electrical installation identified overleaf at the time it was inspected and tested, taking into account the stated extent of the installation and the limitations of the inspection and testing.

The report identifies any damage, deterioration, defects and/or conditions found by the inspector which may give rise to danger (see Section F), together with any items for which improvement is recommended.

If you were the person ordering this report, but not the user of the installation, you should pass this report, or a full copy of it including these notes, the schedules and additional pages (if any), immediately to the user.

This report should be retained in a safe place and shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this report will provide the new user with an assessment of the condition of the electrical installation at the time the periodic inspection was carried out.

Where the installation incorporates residual current devices (RCDs), there should be a notice at or near the consumer unit stating that they should be tested quarterly. FOR SAFETY REASONS, IT IS IMPORTANT THAT YOU CARRY OUT THE TEST REGULARLY.

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection should be carried out is stated in Section I of this report. There should also be a notice at or near the consumer unit indicating when the next inspection of the installation is due. NICEIC* recommends that you engage the services of an Approved Contractor for the inspection.

This report has been issued in accordance with the national standard for the safety of electrical installations, British Standard 7671 (as amended) – *Requirements for Electrical Installations*.

Only an NICEIC Approved Contractor or Conforming Body is authorised to issue this NICEIC Domestic Electrical Installation Condition Report form.

You should have received the report marked 'Original' and the Approved Contractor should have retained the report marked 'Duplicate'.

The report consists of at least seven numbered pages. Additional numbered pages may have been provided to permit further relevant information relating to the installation to be recorded. For installations having more than one consumer unit or more circuits than can be recorded on Page 7, one or more additional *Schedules of Circuit Details and Test Results for the Installation* should form part of the report. The report is invalid if any of the pages identified in Section H are missing. The report has a printed seven-digit serial number, which is traceable to the NICEIC Approved Contractor to which it was supplied by NICEIC.

This report form is intended to be issued only for the purpose of reporting on the condition of an existing domestic electrical installation. The report should identify, so far as is reasonably practicable and having regard to the extent and limitations recorded in Section D, any damage, deterioration, defects, dangerous conditions and any non-compliances with the requirements of the national standard for the safety of electrical installations which may give rise to danger, together with any items for which improvement is recommended.

The report should not have been issued to certify that new electrical installation work complies with the requirements of the national safety standard. An 'Electrical Installation Certificate', a 'Domestic Electrical

Installation Certificate' or a 'Minor Electrical Installation Works Certificate' (as appropriate) should be issued for the certification of new installation work.

Section D (*Extent and limitations*) should identify fully the extent of the installation covered by this report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Some operational limitations may have been encountered during the inspection such as inability to gain access to parts of the installation or to an item of equipment. The inspector should have noted any such limitations in Section D.

It should be noted that the greater the limitations applying to a report, the less its value from the safety aspect.

A declaration of the overall condition of the installation should have been given by the inspector in Section G of the report. The declaration must reflect the statement given in Section E, which summarises the observations and recommendations made in Section F. Where one or more observations have been made in Section F, the Classification code given to each by the inspector indicates the degree of urgency with which remedial action needs to be taken to restore the installation to a safe working condition.

Where the inspector has indicated an observation or code C1 (*danger present*) the safety of those using the installation is at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.

Where the inspector has indicated an observation or code C2 (*potentially dangerous*) the safety of those using the installation may be at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where the inspector has indicated further investigation (FI), the investigation should be carried out without delay to determine whether danger or potential danger exists. For further guidance on the Classification codes, please see the reverse of page 2.

Where the installation can be supplied by more than one source, such as the public supply and a standby generator or microgenerator, the number of sources should have been recorded in Section K *Supply Characteristics and Earthing Arrangements* on page 3 of the report, and the *Schedule of Test Results* compiled accordingly.

Where inadequacies in the electricity distributor's or supplier's equipment have been observed (Section 1 of the *Schedule of Inspections*), the person ordering the inspection should inform the distributor and/or supplier as appropriate.

Should the person ordering this report have reason to believe that it does not reasonably reflect the condition of the electrical installation reported on, that person should in the first instance raise the specific concerns in writing with the NICEIC Approved Contractor. If the concerns remain unresolved, the person ordering this report may make a formal complaint to NICEIC, for which purpose a complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

* NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).

For further information about electrical safety
and how NICEIC can help you, visit www.niceic.com

Continued on the reverse of page 3

GUIDANCE FOR RECIPIENTS ON THE CLASSIFICATION CODES

Only one Classification code should have been given for each recorded observation.

Classification code C1 (*Danger present*)

Where an observation has been given a Classification code C1, the safety of those using the installation is at risk and immediate remedial action is required.

The person responsible for the maintenance of the installation is advised to take action without delay to remedy the observed deficiency in the installation, or to take other appropriate action (such as switching off and isolating the affected part(s) of the installation) to remove the danger. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

NICEIC makes available 'Electrical Danger Notification' forms to enable inspectors to record, and then to communicate to the person ordering the report, any dangerous condition discovered.

Classification code C2 (*Potentially dangerous*)

Classification code C2 indicates that, whilst those using the installation may not be at immediate risk, **urgent remedial action is required to remove potential danger**. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

Classification code C3 (*Improvement recommended*)

Where an observation has been given a Classification code C3, the inspection and/or testing has revealed a non-compliance with the current safety standard which, whilst not presenting immediate or potential danger, would result in a significant safety improvement if remedied. Careful consideration should be given to the safety benefits of improving these aspects of the installation. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

It is important to note that the recommendation given at Section I of this report (Next Inspection) for the maximum interval until the next inspection is conditional upon all items which have been given a Classification code C1 and code C2 being remedied immediately and as a matter of urgency, respectively.

It would not be reasonable for the inspector to indicate that the installation is in a satisfactory condition if any observation in this report has been given a code C1 or code C2 classification.

Code FI (*Further investigation required without delay*)

It should usually be possible for the inspector to attribute a Classification code to each observation without indicating a need for further investigation.

However, where 'FI' has been entered against an observation the inspector considers that further investigation of that observation is likely to reveal danger or potential danger that, due to the agreed extent or limitations of the inspection and/or testing, could not be fully identified at the time.

It would not be appropriate for the inspector to indicate that the installation is in a satisfactory condition if there is reasonable doubt as to whether danger or potential danger exists. Consequently, where the inspector has indicated further investigation required without delay (FI) the overall assessment of the installation (Section E) should be marked as unsatisfactory.

If the inspector has indicated that an observation requires further investigation without delay, the person ordering this report is advised to arrange for the NICEIC Approved Contractor issuing the report (or another skilled person or persons competent in such work) to undertake further examination of that aspect of the installation as a matter of urgency, to determine whether or not danger or potential danger exists.

Further information

Further information on the application of Classification codes, primarily aimed at inspectors but of possible interest to persons ordering condition reports, can be found in Electrical Safety First's Best Practice Guide entitled *Electrical installation condition reporting: Classification Codes for domestic and similar electrical installations*. The guide can be viewed or downloaded free of charge from www.electricalsafetyfirst.org.uk

January 2015

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

F. OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

Referring to the attached schedules of inspection and test results, and subject to the limitations at D:

There are **no** items adversely affecting electrical safety **or** The following observations and recommendations for action are made

Item No	Observations	Code †
1	4.4 The consumer unit is plastic, AMD 3 states that it should be metal.	C3
2	5.10.1 Access restriction	LIM

Additional pages? No Yes Specify page No(s):

† One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action:

Code C1 'Danger present'. Risk of injury. Immediate remedial action required.

Code C2 'Potentially dangerous'. Urgent remedial action required.

Code C3 'Improvement recommended'.

Code FI 'Further investigation required without delay'.

Please see the reverse of this page for guidance regarding the Classification codes.Immediate remedial action
required for items: Urgent remedial action
required for items: Further investigation required
without delay for items: Improvement
recommended for items:

1

G. DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described on page 1 (see C), having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (see F) and the attached schedules (see H), provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing (see D).

I/We further declare that in my/our judgement, the overall assessment of the installation in terms of its suitability for continued use is **SATISFACTORY** ~~UNSATISFACTORY~~ Delete as appropriate

(see F) at the time the inspection was carried out, and that it should be further inspected as recommended (see I).

* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

INSPECTION, TESTING AND ASSESSMENT BY:

Signature: Name: (CAPITALS) **DAVE WEBBER**

Position: Director

Date: 10/10/2018

REPORT REVIEWED AND CONFIRMED BY:

Signature: Name: (CAPITALS) **DAVE WEBBER***(Registered Qualified Supervisor for the Approved Contractor at J)*

Date: 10/10/2018

H. SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspections: Page(s) No 4, 5, 6

Additional pages, including data sheets for additional source(s): Page No(s)

Schedule of Circuit Details for the Installation: Page No(s) 7, 8, 9

Schedule of Test Results for the Installation: Page No(s) 7, 8, 9

The pages identified are an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.

Please see the 'Guidance for Recipients on the Classification codes' on the reverse of this page.

Page 2 of 8

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than:

5

(Enter interval in terms of years or months, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or FI (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading title: Wave Electrical Services

Address: Unit 2 River Court
Saltash

Telephone number: 01752 717377

Email address: davewebber@waveservices.co.uk



Enrolment number: 6 0 7 1 8 3
(Essential information)

Branch number: 0 0 0
(if applicable)

Postcode: PL12 6LE

K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Tick boxes or enter details as appropriate

System type(s)	Number and type of live conductors		Nature of supply parameters				Characteristics of primary supply overcurrent protective device(s)			
TN-S <input checked="" type="checkbox"/>	a.c. <input checked="" type="checkbox"/>	Other (please state)	Nominal voltage(s) $U^{(1)}$	230	V	$U_0^{(1)}$	N/A	V	BS(EN)	1361
TN-C-S <input type="checkbox"/>	1-phase (2-wire) <input type="checkbox"/>	1-phase (3-wire) <input checked="" type="checkbox"/>	Nominal frequency, $f^{(1)}$	50	Hz	Number of sources	1		Type	2
TT <input type="checkbox"/>	2-phase (3-wire) <input type="checkbox"/>	3-phase (4-wire) <input type="checkbox"/>	Prospective fault current, $I_{pf}^{(2)(3)}$	1.14	kA	Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement			Rated current	100 A
	3-phase (3-wire) <input type="checkbox"/>		External earth fault loop impedance, $Z_e^{(3)(4)}$	0.20	Ω				Short-circuit capacity	16 kA
									Confirmation of supply polarity	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Tick boxes or enter details as appropriate

Means of earthing			Details of installation earth electrode (where applicable)		
Distributor's facility: <input checked="" type="checkbox"/>	Type: (eg rod(s), tapes etc)	N/A	Location:	N/A	
Installation earth electrode: <input type="checkbox"/>	Electrode resistance, R_A :	N/A (Ω)	Method of measurement:	N/A	

Main Switch/Switch-Fuse/Circuit-Breaker/RCD			Earthing and protective bonding conductors		
Type BS(EN)	60947-3	Voltage rating	230	V	Earthing conductor
No of poles	2	Rated current, I_n	100	A	
Primary supply conductors (material)	copper	RCD operating current, $I_{\Delta n}^*$	N/A	mA	Main protective bonding conductors
Primary supply conductors (csa)	25 mm ²	Rated time delay*	N/A	ms	
		RCD operating time (at $I_{\Delta n}^*$)	N/A	ms	Bonding of extraneous-conductive-parts (✓)
* (applicable only where an RCD is suitable and is used as a main circuit-breaker)					
			Conductor material	copper	Water installation pipes <input checked="" type="checkbox"/>
			Conductor csa	16 mm ²	
			Connection/continuity verified	<input checked="" type="checkbox"/> (✓)	Oil installation pipes <input type="checkbox"/>
					Structural steel <input type="checkbox"/>
					Gas installation pipes <input checked="" type="checkbox"/>
					Other (Specify)

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference	Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment[†]			4.0	Consumer unit(s)		
1.1	Service cable	✓		4.1	Adequacy of working space or access to consumer unit	✓	
1.2	Service head	✓		4.2	Security of fixing	✓	
1.3	Distributor's earthing arrangement	✓		4.3	Condition of enclosure(s) in terms of IP rating	✓	
1.4	Meter tails - Distributor/Consumer	✓		4.4	Condition of enclosure(s) in terms of fire rating	C3	DB2
1.5	Metering equipment	✓		4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	
1.6	Means of main isolation (where present)	✓		4.6	Presence of linked main switch	✓	
2.0	Presence of adequate arrangements for other sources (microgenerators etc)			4.7	Operation of main switch (functional check)	✓	
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A		4.8	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	✓	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A		4.9	Correct identification of circuits and protective devices	✓	
3.0	Earthing and bonding arrangements			4.10	Presence of RCD test notice at or near consumer unit	✓	
3.1	Presence and condition of distributor's earthing arrangement	✓		4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	✓	
3.2	Presence and condition of earth electrode connection	N/A		4.12	Presence of alternative or additional supply warning notice at or near consumer unit	✓	
3.3	Confirmation of adequate earthing conductor size	✓		4.13	Presence of replacement next inspection recommendation label	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓		4.14	Presence of other required labelling (please specify)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes	✓		4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
3.6	Accessibility and condition of main protective bonding conductor connections	✓		4.16	Single-pole switching or protective devices in the line conductors only	✓	
3.7	Accessibility and condition of other protective bonding connections	✓		4.17	Protection against mechanical damage where cables enter consumer unit	✓	
3.8	Provision of earthing and bonding labels at all appropriate locations	✓					

[†] Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.

* All boxes must be completed.

✓ indicates **Acceptable condition**

⊘ indicates a **Limitation**

'N/A' indicates **Not applicable**

Unacceptable condition state **C1** or **C2**

Improvement recommended state **C3**

Further investigation required without delay state **F1**

(to determine whether danger or potential danger exists)

Outcome

Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and F1 coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference	Item	Description	Outcome*	Location reference
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	✓			• incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations)	✓	
4.19	RCDs provided for fault protection – includes RCBOs	✓					
4.20	RCDs provided for additional protection – includes RCBOs	✓		5.11	Provision of additional protection by RCD not exceeding 30 mA		
4.21	Confirmation of indication that SPD is functional	N/A			• †for all socket-outlets of rating 20 A or less	✓	
4.22	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓			• †for mobile equipment not exceeding a rating of 32A for use outdoors	✓	
					• †for cables installed in walls or partitions at a depth of less than 50 mm	✓	
					• †for cables installed in walls / partitions containing metal parts regardless of depth	✓	
5.0	Distribution/final circuits			5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects		
5.1	Identification of conductors	✓		5.13	Band II cables segregated/separated from Band I cables		
5.2	Cables correctly supported throughout their length	✓		5.14	Cables segregated/separated from communications cabling		
5.3	Condition of insulation of live parts	✓		5.15	Cables segregated/separated from non-electrical services	✓	
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	✓		5.16	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓			• Connections soundly made and under no undue strain	✓	
5.6	Adequacy of protective devices; type and rated current for fault protection	✓			• No basic insulation of a conductor visible outside enclosures	✓	
5.7	Presence and adequacy of circuit protective conductors	✓			• Connections of live conductors adequately enclosed	✓	
5.8	Co-ordination between conductors and overload protective devices	✓			• Adequately connected at point of entry to enclosure (glands, bushes etc.)	✓	
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓		5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	
5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage			5.18	Suitability of accessories for external influences	✓	
	• installed in prescribed zones (see Section D. Extent and limitations)	LIM	Under Floors				

† Note: Older installations designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection

* All boxes must be completed.

✓ indicates **Acceptable condition**
 LIM indicates a **Limitation**

'N/A' indicates **Not applicable**
 Unacceptable condition state **C1** or **C2**
 Improvement recommended state **C3**

Further investigation required without delay state **F1**
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and F1 coded items to be recorded in Section F of the report.

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT (FOR A SINGLE DWELLING)

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Location reference	Item	Description	Outcome*	Location reference
5.19	Adequacy of working space / accessibility to equipment	✓		7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire <i>List number and location of luminaires inspected. (Separate page)</i>	✓	
5.20	Single-pole devices for switching or protection in line conductors only	✓		7.7	Recessed luminaires (downlighters)		
6.0 Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)					• correct type of lamps fitted	✓	
6.1 In general					• installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	✓	
	• presence and condition of appropriate devices	✓			• no signs of overheating to surrounding building fabric	✓	
	• correct operation verified	✓			• no signs of overheating to conductors/terminations	✓	
6.2 For isolation and switching for mechanical maintenance only				8.0 Location(s) containing a bath or shower			
	• capable of being secured in the OFF position where appropriate	✓		8.1 Additional protection by RCD not exceeding 30 mA			
	• acceptable location – state if local or remote from equipment being controlled where appropriate	✓			• for low voltage circuits serving the location		
	• clearly identified by position and/or durable marking(s)	✓			• for low voltage circuits passing through Zone 1 and Zone 2 not serving the location		
6.3 For isolation only				8.2	Where used as a protective measure, requirements for SELV or PELV are met	N/A	
	• warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	✓		8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	N/A	
7.0 Current-using equipment (Permanently connected)				8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	N/A	
7.1	Condition of equipment in terms of IP rating	✓		8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	N/A	
7.2	Equipment does not constitute a fire hazard	✓		8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety	✓		8.7	Suitability of equipment for installation in a particular zone	✓	
7.4	Suitability for the environment and external influences	✓		9.0 Other special installations or locations - Part 7s			
7.5	Security of fixing	✓		9.1	List all other special installations or locations present, if any. (Record the results of particular inspection applied separately).	N/A	

* All boxes must be completed.

✓ indicates **Acceptable condition**
 'LIM' indicates a **Limitation**

'N/A' indicates **Not applicable**
 Unacceptable condition state **C1** or **C2**
 Improvement recommended state **C3**

Further investigation required without delay state **FI**
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

SCHEDULES

CIRCUIT DETAILS										TEST RESULTS																					
Circuit number	Circuit designation <i>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</i>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD	Maximum Z_s permitted by BS 7671	Circuit impedances (Ω)						Insulation resistance				Polarity	Maximum measured earth fault loop impedance, Z_s (Ω)	RCD operating times		Test button operation			
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Operating current, $I_{\Delta n}$ (mA)	Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)			Line/Line (M Ω)	Line/Neutral (M Ω)	Line/Earth (M Ω)			Neutral/Earth (M Ω)	at $I_{\Delta n}$ (ms)		at 5 $I_{\Delta n}$ (if applicable) (ms)		
												r_1 (Line)			r_n (Neutral)	r_2 (cpc)	$(R_1 + R_2)$	R_2													
					*																										
1	Shower	A	B	1	6	2.5	0.4	60898	B	32	6	30	1.36	N/A	N/A	N/A	0.09	N/A	N/A	500	500	500	✓	0.14	34	15	✓				
2	Kitchen Sockets	A	B	7	2.5	1.5	0.4	60898	B	32	6	30	1.36	0.41	0.42	0.65	0.21	N/A	N/A	500	500	500	✓	1.03	34	15	✓				
3	SPARE																														
4	SPARE																														
5	ext Lights	A	B	2	1.5	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.9	N/A	N/A	500	500	500	✓	0.51	34	15	✓				
6	SPARE																														
7	SPARE																														
8	Sockets	A	B	4	2.5	1.5	0.4	60898	B	16	6	30	2.73	N/A	N/A	N/A	0.29	N/A	N/A	500	500	500	✓	0.44	27	18	✓				
9	Cooker	A	B	1	6	2.5	0.4	60898	B	32	6	30	1.36	N/A	N/A	N/A	0.14	N/A	N/A	500	500	500	✓	0.39	27	18	✓				
10	SPARE																														

Location of consumer unit Designation of consumer unit **DB2** Prospective fault current kA

TEST INSTRUMENTS

Test instruments (serial numbers) used

Multi-function Insulation resistance Continuity Earth electrode resistance Earth fault loop impedance RCD

CODES FOR TYPE OF WIRING			
			0 (Other - please state)
			H Mineral-insulated cables
			G Thermosetting SWA cables
			F Thermoplastic SWA cables
			E Thermoplastic cables in metal trunking
			D Thermoplastic cables in metal trunking
			C Thermoplastic cables in non-metallic conduit
			B Thermoplastic cables in non-metallic conduit
			A Thermoplastic sheathed cables

Original (To the person ordering the work)

SCHEDULES - CONTINUATION

CIRCUIT DETAILS													TEST RESULTS																										
Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD	Maximum Z _s permitted by BS 7671	Circuit impedances (Ω)				Insulation resistance				Polarity	Maximum measured earth fault loop impedance, Z _s (Ω)	RCD															
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Operating current, I _{nb} (mA)	Ring final circuits only (measured end to end)			Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)			operating times		Test button operation													
															r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)							(R ₁ + R ₂)	R ₂		at I _{Δn} (ms)	at 5 I _{Δn} (if applicable) (ms)											
					*																																		
1	Shower	A	B	1	6	2.5	0.4	60898	B	32	6	30	1.36	N/A	N/A	N/A	0.14	N/A	N/A	500	500	500	✓	0.42	24.1	13.2	✓												
2	Unknown (D/C)																																						
3	Unknown (D/C)																																						
4	Lights (D/C)																																						
5	Room 1/2 Sockets	A	B	5	2.5	1.5	0.4	60898	B	32	6	30	1.36	LIM	LIM	LIM	0.33	N/A	N/A	500	500	500	✓	0.56	24.1	13.2	✓												
6	Sockets up	A	B	9	2.5	1.5	0.4	60898	B	32	6	30	1.36	N/A	N/A	N/A	0.33	N/A	N/A	500	500	500	✓	0.88	25.9	13	✓												
7	SPARE																																						
8	Lights up	A	B	5	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.69	N/A	N/A	500	500	500	✓	1.09	25.9	13	✓												
9	Lights	A	B	3	1	1	0.4	60898	B	6	6	30	7.28	N/A	N/A	N/A	0.54	N/A	N/A	500	500	500	✓	0.95	25.9		✓												

CODES FOR TYPE OF WIRING	
A	Thermoplastic cables in non-metallic conduit
B	Thermoplastic cables in non-metallic conduit
C	Thermoplastic cables in non-metallic conduit
D	Thermoplastic cables in metallic trunking
E	Thermoplastic cables in metallic trunking
F	Thermoplastic cables in metallic trunking
G	Thermoplastic cables in metallic trunking
H	Mineral-insulated cables
0 (Other - please state)	

Location of consumer unit	Designation of consumer unit	DB1	Prospective fault current at consumer unit	kA
TEST INSTRUMENTS <i>Test instruments (serial numbers) used</i>				
Multi-function	Insulation resistance	Continuity	Earth electrode resistance	Earth fault loop impedance
				RCD

Original (To the person ordering the work)