



To confirm the validity of the Registered Gas Safe on 0800 408 5500 or www.gassaferegister.co.uk

LANDLORD/HOMEOWNER GAS SAFETY RECORD

This form allows for the recording of results of checks as defined by the Gas Safety (Installation and Use) Regulations. Information recorded on this form does not confirm that the installation was installed by a Gas Safe registered business or that the installation complies with relevant Building Regulations. Chimney/flue/outlets were visually checked for adequate evacuation of combustion products. A detailed internal inspection has not been undertaken.

Serial No:
9466599

DETAILS OF REGISTERED BUSINESS

GLENN JENKINS BOILER REPAIRS
 Gas Safe Reg. No: 16657
 111 MERAFIELD DRIVE,
 PLYMOUTH, PL7 1TR
 Tel. No: 07836 716 277

JOB ADDRESS

Name: [Blank]
 Address: 13 Nelson Street
 Tel. No: [Blank]
 No. Of Appliances Tested: Two

LANDLORD/AGENT ADDRESS

Name: JSM
 Address: [Blank]
 Tel. No: [Blank]
 No. Of Appliances Tested: Two

Appliance Location	Appliance Make	Appliance Model	Appliance Type	Type of Flue (OF/RS/FL)	Landlords Appliance (Y/N)	Appliance Inspected (Y/N)
1 Kitchen	Glenn Jenks	flexicom 24cx	Boiler	RS	Y	Y
2 Kitchen	Diplomat	4 ring	Hob	FL	Y	Y
3						
4						
5						

Operating Pressure in mbar and or Heat Input in KW/Btu/h	Are Safety Devices Working? (Y/N)	Satisfactory Ventilation? (Y/N)	Flue Visual Condition (Pass/Fail/NA)	Flue Performance Checks (Pass/Fail/NA)	Combustion Analyser Reading		Appliance Serviced (Y/N)	Appliance Safe To Use (Y/N)	CO Alarm	
					CO: CO2 Ratio	CO PPM			Approved CO Alarm Fitted? (Y/N)	Does The CO Alarm Work? (Y/N)
20	Y	Y	PASS	PASS	0.0004	46	Y	Y	Y	Y
17	NA	Y	NA	NA	NA	NA	Y	Y	Y	Y

Defect(s) Identified	Warning Advice Issued? (Y/N)	Remedial Work Undertaken	Details Of Work Required
2			
3			
4			
5			

Received By: [Signature] Date: [Blank]

Print Name: [Blank] Date: 25/8/17

Issued By: J Zachary ID Card No: 16657 Date: 25/8/17

The Next Gas Safety Check Must Be Completed By: 25/8/18