	Dor Safe Heat Gas & Plumbing BOILER REPLACEMENT SPECIALISTS Inspection Date: 22					estic Landlord Gas Safety Record					No. of A Ref:	Page No 1 of 1 No. of Appliances Inspected: 1 Ref: 33WR24EWLGSR Gas Safe Reg No: 221090						
Landlord / Agent Details						Site Details						Registered Business Details						
Na	Name: Perry Bowden					me: Stu	Students Name:					SAFE HEAT GAS & PLUMBING						
Ad	dress:	Pemberley Cott	age		Add	dress: 33 I	33 Bransford Road Address:					50 Quee	50 Queens Road					
		Stocks Lane, Newland, Malvern				St J	St Johns					Sedgley						
		Worcestershire			Worcester							West Midlands						
Po	stcode:	WR13 5AZ			Pos	stcode: WR	WR2 4EW				Postcode:	DY3 1HL						
Te	lephone:		Mobile:	07432604880	Tele	ephone:		Mobile:			Telephone:	01902 5	64131	Mobile:	07889190113			
Appliance Details					tails				Inspection Details									
	Location		Appliance Type	Make		Model	Flue Type FL/ OF / RS-BF / RS-FF	Landlord's Appliance (if applicable) Yes / No / NA			Safety device(s) correct operation Yes /No /NA	Ventilation provision satisfactory Yes/No	Visual condition of flue and termination satisfactory Yes/No/NA	Checks Pass / Fail / NA	Appliance serviced Yes / No	Appliance safe to use Yes / No		
1	Lounge / l	nge / Living Room Combi Boiler Ferroli Mode		Modena 80	dena 80E		Yes	Yes	/es 24.6 kW/h		Yes	Yes	n/a	Yes	Yes			
2																		
3																		
4																		

Defects Identified	Remedial Action Taken	Warning Notice issued	Combustion Analysis Readings								
		Yes (serial) / No	1st Reading/Min/Low			2nd Reading/Max/High			3rd Reading/Ign/Other		
			CO	CO2	Ratio	CO	CO2	Ratio	CO	CO2	Ratio
1			35	4.99%	.0006	22	2.58%	.0009	N/A	N/A	N/A
2											
3											
4											
5											
6											

F	inal Chec	ks			Sign-off				Flue Types Key					
Gas Tightness Test initial value	e: 20 mbar	TT final	value: 2	20 mbar	This Safety record is				FL - Flueless					
Satisfactory gas tightness test	Yes/No/NA			Yes	issued by: Signed			$\geq \frown$	OF - Open Flue					
Gas installation pipework satis		nspection	Yes/No	Yes			<u> </u>		RS-BF - Room sealed balanced flue RS-FF - Room sealed fan flue					
Emergency Control accessible	Yes/No			Yes	Gas Operative: Gavin Priest									
Main Protective Equipotential E	Bonding satisf	actory Yes	/No	Yes	Operative ID No:	4303617	Data	22 August 2019	NEXT SAFETY CHECK DUE					
CO alarm present? Yes C	O alarm worki	alarm working? Yes In date? Yes Preceived by: Signed Operative ID No: 4303617 Date: 22 August 2018						22 August 2018	BEFORE 22 August 2019					
Smoke alarm(s) present?	Yes Smok	e alarm(s) working? Yes					S							
This inspection is for gas safet Safety (Installation and Use) R checked for satisfactory evacua	egulations. Flu	ies were v	isually insp	ected and		VQ								
internal inspection of the flue in					Name:	Perry Bowden			This certificate was produced using The Master Gas					
carried out.	itegrity, constr		ining has	not been	Position:	Landlord	Date:	22 August 2018	App. Copyright Gas Installers Workmate Ltd.					