

GAS SAFETY CERTIFICATE

Serial No: 46C 0980633

To comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

INSPECTION/INSTALLATION ADDRESS

Name & Title: Amy Kearney
 Address: 143 J CORPORATION STREET
STAFFORD
 Postcode: ST16 3LS Tel: _____
 Rented: Yes: No:

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title: PRICE HOMES 444
 Address: CHASEVIEW FARM
PWDDLE HILL
HIXON
 Postcode: ST18 0NG Tel: 07854 830 214

DESCRIPTION OF WORK CARRIED OUT

DETAILS

Type	Flue Type OFRS/FL	Operating pressure in mbar or heat input kW/h or Btu/h	Safety device(s) correct operation		FLUE TESTS			INSPECTION DETAILS							
			Yes/No/NA	Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet flue flow test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance Yes/No/NA	Inspected Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No
BOKER RS		35kW	YES	YES	PASS	NA	0.009	0.009	YES	PASS	YES	YES	YES	YES	YES
HOB	FL	7.9kW	YES	YES	NA	NA	-	-	NA	NA	YES	YES	YES	NO	YES

Emergency Control Accessible: Yes No

Satisfactory Gas Tightness Test: Yes No

Equipotential Bonding Satisfactory: Yes No

ANY FAULTS

RECTIFICATION WORK CARRIED OUT		WARNING NOTICE ISSUED Year/No/NA	WARNING TAG or STICKER FIXED Year/No/NA

Are CO Alarms in Date: Yes No N/A

Testing of CO Alarms Satisfactory: Yes No N/A

Smoke Alarms Fitted: Yes No N/A

Print Name: Rob Paducale

Date: 2nd Aug 2018

Date: 2nd Aug 2018

NEXT GAS SAFETY CHECK MUST BE CARRIED OUT WITHIN 12 MONTHS

Signature: Amy Kearney Print Name: _____ Date: _____
 Signature: Rob Paducale Print Name: Rob Paducale Date: 2nd Aug 2018
 Signature: _____ Print Name: _____ Date: _____

Landlord/Tenant (if rented)

BF461708

* IF YES, PLEASE REFER TO SEPARATE WARNING/ADVICE NOTICE

Form Ref. REGP46