

ELECTRICAL INSTALLATION CONDITION REPORT

Certificate number: [] Registration number: 31188 (optional) Sheet [] of []

SECTION A: DETAILS OF THE CLIENT / PERSON ORDERING THE REPORT

Name: FLAGSHIP Address: KESWICK HALL KESWICK NORWICH

SECTION B: REASON FOR PRODUCING THIS REPORT

Date(s) on which inspection and testing was carried out

SECTION C: DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT

Occupier: Student ACCOMMODATION Address: BLOCK H TRIPAS COURT, HOMEKTON STREET, CAMBRIDGE, CB2 8NY

Description of premises (tick as appropriate) Domestic [] Commercial [] Industrial [] Other (include brief description) RESIDENTIAL student accommodation Estimated age of wiring system 15 years Evidence of additions / alterations Yes [x] No [] Not apparent [] If yes, estimate age Various years Installation records available? (Regulation 621.1) Yes [] No [x] Date of last inspection JUNE 2009 (date)

SECTION D: EXTENT AND LIMITATIONS OF INSPECTION AND TESTING

Extent of electrical installation covered by this report All FIXED WIRING

Agreed limitations including the reasons (see Regulation 634.2) 100% of all Students Rooms, 10% of all Commercial areas

Operational limitations including the reasons (see page no.) The inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671:2008 (IET Wiring Regulations) as amended to It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces and generally within the fabric of the building or underground, have NOT been inspected unless specifically agreed between the client and inspector prior to inspection.

SECTION E: SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety) Good when all Remedial works Rectified

Overall assessment of the installation in terms of its suitability for continued use SATISFACTORY / UNSATISFACTORY * (delete as appropriate) An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified

SECTION F: RECOMMENDATIONS

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I/we recommend that any observations classed as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further investigation required' Observations classified as 'Improvements recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by Jan 15 (date)

SECTION G: DECLARATION

I/We being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in Section D of this report.

Inspected and tested by: Name (CAPITALS): A. MOFFATT Signature: A. Moffatt For/on behalf of: Blue Flame Services Position: A. Moffatt Address: 2 Commerce Park, Whitehall Road, Colchester, Essex, CO2 8HX Date: 11/9/14

Report authorised for issue by: Name (CAPITALS): G. Gilbert Signature: G. Gilbert For/on behalf of: Blue Flame Services Position: G Gilbert Address: 2 Commerce Park, Whitehall Road, Colchester, Essex, CO2 8HX Date: 16/10/14

SECTION H: SCHEDULE(S)

schedule(s) of inspection and schedule(s) of test results are attached. The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

ELECTRICAL INSTALLATION CONDITION REPORT

SECTION I: SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing arrangements	Number and type of live conductors	Nature and type of supply parameters	Supply protective device
TN-C <input type="checkbox"/>	a.c. <input checked="" type="checkbox"/> d.c. <input type="checkbox"/>	Nominal voltage, U / U ₀ ⁽¹⁾ ... 400 / 230 V	BS (EN) ... 60947-2
TN-S <input type="checkbox"/>	1-phase, 2 wire <input type="checkbox"/> 2-wire <input type="checkbox"/>	Nominal frequency, f ⁽¹⁾ ... 50 Hz	Type... -
TN-C-S <input checked="" type="checkbox"/>	2-phase, 3 wire <input type="checkbox"/> 3-wire <input type="checkbox"/>	Prospective fault current, I _p ⁽²⁾ ... 2.4 kA	Rated current ... 250 A
TT <input type="checkbox"/>	3-phase, 3 wire <input type="checkbox"/>	External loop impedance, Z _e ⁽²⁾ ... 0.06 Ω	
IT <input type="checkbox"/>	3-phase, 4 wire <input checked="" type="checkbox"/>	Note: (1) by enquiry. (2) by enquiry or measurement	
	Confirmation of supply polarity <input checked="" type="checkbox"/>		

Other sources of supply (as detailed on attached schedule)

SECTION J: PARTICULARS OF INSTALLATION REFERRED TO IN REPORT

Means of earthing	Details of Earth Electrode (where applicable)
Distributor's facility <input checked="" type="checkbox"/>	Type... /
Installation earth electrode <input type="checkbox"/>	Location... / Resistance to earth... Ω

Main protective conductors

Earthing conductor	Material ... COPPER	Csa ... 35 mm ²	Connection/continuity verified <input checked="" type="checkbox"/>
Main protective bonding conductors	Material ... COPPER	Csa ... 35 mm ²	Connection/continuity verified <input checked="" type="checkbox"/>
To incoming water service <input checked="" type="checkbox"/>	To incoming gas service <input type="checkbox"/>	To incoming oil service <input type="checkbox"/>	To structural steel <input type="checkbox"/>
To lightning protection <input type="checkbox"/>	To other incoming service(s) <input type="checkbox"/>	Specify ...	

Main switch / switch fuse / circuit breaker / RCD

Location ... BLOCK H GROUND FLOOR	Current rating ... 250 A	If RCD main switch
UNOCC STAIRS UPBOARD	Fuse / device rating or setting ... 32 kA	Rated residual operating current (I _{Δn}) ... mA
BS (EN) ... 60947-2	Voltage rating ... 415 V	Rated time delay ... ms
No. of poles ... 4		Measured operating time (at I _{Δn}) ... ms

SECTION K: OBSERVATIONS

Referring to the attached schedules of inspection and test results, and subject to the limitations specified in the *Extent and Limitations of Inspection and testing section*

No remedial action is required The following observations are made: (See below)

Observation(s)	Classification code	Further investigation required (YES/NO)
1) DISTRIBUTION BOARDS NOT LABELLED:- LANOLOARDS	C3	
2) DB H1 CIRCUIT 3L1 NO CONTINUITY ON RIBB N-N	C2	YES
3) DB H1 COOKER CIRCUITS 1L1 + 2L2 WRONG POLARITY L-N REVERSE	C3	
4) WALL LIGHT IN ROOM H2 NOT FIXED SECURELY	C3	
5) BROKEN DOUBLE SOCKET H10 + H8	C2	
6) LIGHT WALL H7-12 NOT SECURELY FIX60	C3	
7) DB H3 COOKER CIRCUITS WRONG POLARITY IN ISOLATORS	C3	
8) BROKEN DOUBLE SOCKET ROOM H11	C2	
9) DIFFUSER MISSING H25-30 KITCHEN LIGHT		
10) NO EARTH AT ONE HALF DOUBLE SOCKET IN H25-30 KITCHEN + H29 LOW	C1	YES
11) NO RCD PROTECTION ON ANY CIRCUITS	C3	
12) LIGHT SECOND FLOOR STAIR WEL NOT SECURELY FIX60		
FANS NOT WORKING:- H2/H10/H22		

One of the following codes, as appropriate, has been allocated to each of the observations made to indicate to the person(s) responsible for the installation the degree of urgency of remedial action required.

- C1 - Danger present. Risk of injury. Immediate remedial action required
- C2 - Potentially dangerous. Urgent remedial action required
- C3 - Improvement recommended

Use additional form if required

ELECTRICAL INSTALLATION CONDITION REPORT

SECTION I: SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing arrangements	Number and type of live conductors	Nature and type of supply parameters	Supply protective device
TN-C <input type="checkbox"/>	a.c. <input type="checkbox"/> d.c. <input type="checkbox"/>	Nominal voltage, U / U ₀ ⁽¹⁾ V	BS (EN)
TN-S <input type="checkbox"/>	1-phase, 2 wire <input type="checkbox"/> 2-wire <input type="checkbox"/>	Nominal frequency, f ⁽¹⁾ Hz	Type
TN-C-S <input type="checkbox"/>	2-phase, 3 wire <input type="checkbox"/> 3-wire <input type="checkbox"/>	Prospective fault current, I _{pf} ⁽²⁾ kA	Rated current A
TT <input type="checkbox"/>	3-phase, 3 wire <input type="checkbox"/>	External loop impedance, Z _e ⁽²⁾ Ω	
IT <input type="checkbox"/>	3-phase, 4 wire <input type="checkbox"/>	Note: (1) by enquiry (2) by enquiry or measurement	
	Confirmation of supply polarity <input type="checkbox"/>		

Other sources of supply (as detailed on attached schedule)

SECTION J: PARTICULARS OF INSTALLATION REFERRED TO IN REPORT

Means of earthing	Details of Earth Electrode (where applicable)
Distributor's facility <input type="checkbox"/>	Type.....
Installation earth electrode <input type="checkbox"/>	Location.....
	Resistance to earth..... Ω

Main protective conductors

Earthing conductor	Material	Csa	mm ²	Connection/continuity verified <input type="checkbox"/>
Main protective bonding conductors	Material	Csa	mm ²	Connection/continuity verified <input type="checkbox"/>
To incoming water service <input type="checkbox"/>	To incoming gas service <input type="checkbox"/>	To incoming oil service <input type="checkbox"/>	To structural steel <input type="checkbox"/>	
To lightning protection <input type="checkbox"/>	To other incoming service(s) <input type="checkbox"/>	Specify.....		

Main switch / switch fuse / circuit breaker / RCD

Location.....	Current rating A	If RCD main switch
.....	Fuse / device rating or setting A	Rated residual operating current (I _{Δn})..... mA
BS (EN)	Voltage rating V	Rated time delay ms
No. of poles		Measured operating time (at I _{Δn}) ms

SECTION K: OBSERVATIONS

Referring to the attached schedules of inspection and test results, and subject to the limitations specified in the *Extent and Limitations of Inspection and testing section*

No remedial action is required The following observations are made: (See below)

Observation(s)	Classification code	Further investigation required (YES/NO)
<u>CONTINUED</u> ⑬ BROKEN SHT IN WARDENS FLAT HALLWAY	C2	✓

One of the following codes, as appropriate, has been allocated to each of the observations made to indicate to the person(s) responsible for the installation the degree of urgency of remedial action required

- C1 – Danger present. Risk of injury Immediate remedial action required
- C2 – Potentially dangerous. Urgent remedial action required
- C3 – Improvement recommended

Use additional form if required

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100 A SUPPLY

NOTE: This form is suitable for many types of smaller installations not exclusively domestic

OUTCOMES	Acceptable condition <input checked="" type="checkbox"/>	Unacceptable condition <input type="checkbox"/>	State C1 or C2 <input type="checkbox"/>	Improvement recommended <input type="checkbox"/>	State C3 <input type="checkbox"/>	Not verified NV <input type="checkbox"/>	Limitation Lim <input type="checkbox"/>	Not applicable N/A <input type="checkbox"/>
Item no	Description	Outcome (Use codes above, provide additional comment where appropriate, C1, C2 and C3 coded items to be recorded in Section K of the Condition Report)					Further investigation required? (YES / NO)	
1.0	DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT							
1.1	Service cable condition	✓						
1.2	Condition of service head	N/A						
1.3	Condition of tails – distributor	N/A						
1.4	Condition of tails – consumer	N/A						
1.5	Condition of metering equipment	✓						
1.6	Condition of isolator (where present)	✓						
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR SECONDARY OR ALTERNATIVE SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)	N/A						
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; chap 54)							
3.1	Presence and condition of distributor's earthing arrangement (542.1.2 1; 542.1 2.2)	✓						
3.2	Presence and condition of earth electrode where applicable (542.1.2.3)	N/A						
3.3	Provision of earthing / bonding labels at all appropriate locations (514.13.1)	✓						
3.4	Confirmation of earthing conductor size (542.3, 543 1.1)	✓						
3.5	Accessibility and condition of earthing conductor at MET (543 3.2)	✓						
3.6	Confirmation of main protective bonding conductor sizes (544.1)	✓						
3.7	Condition and accessibility of main protective bonding conductor connections (543.3 2; 544.1.2)	✓						
3.8	Accessibility and condition of all protective bonding connections (543.3.2)	✓						
4.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)							
4.1	Adequacy of working space / accessibility to consumer unit / distribution board (132.12, 513.1)	✓						
4.2	Security of fixing (134 1.1)	✓						
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)	✓						
4.4	Condition of enclosure(s) in terms of fire rating etc (526.5)	✓						
4.5	Enclosure not damaged / deteriorated so as to impair safety (621.2 iii)	✓						
4.6	Presence of main linked switch (as required by 537.1.4)	✓						
4.7	Operation of main switch (functional check) (612.13.2)	✓						
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (612.13.2)	✓						
4.9	Correct identification of circuit details and protective devices (514 8.1, 514.9 1)	C3						
4.10	Presence of RCD quarterly test notice present at or near consumer unit / distribution board (514.12.2)	N/A						
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit / distribution board (514 14)	N/A						
4.12	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)	N/A						
4.13	Presence of other required labelling (please specify) (Section 514)	N/A						
4.14	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (421.1.3)	✓						
4.15	Single-pole protective devices in line conductor only (132.14.1; 530.3.2)	✓						
4.16	Protection against mechanical damage where cables enter consumer unit / distribution board (522 8.1; 522 8.11)	✓						
4.17	Protection against electromagnetic effects where cables consumer unit / distribution board / enclosures (521.5.1)	✓						
4.18	RCD(s) provided for fault protection – includes RCBOs (411.4.9; 411.5.2, 531 2)	C3						
4.19	RCD(s) provided for additional protection – includes RCBOs(411.3.3, 415 1)	C3						

OUTCOMES	Acceptable condition <input checked="" type="checkbox"/>	Unacceptable condition <input type="checkbox"/>	State C1 or C2 <input type="checkbox"/>	Improvement recommended <input type="checkbox"/>	State C3 <input type="checkbox"/>	Not verified <input type="checkbox"/>	NV <input type="checkbox"/>	Limitation <input type="checkbox"/>	Lim <input type="checkbox"/>	Not applicable <input type="checkbox"/>	N/A <input type="checkbox"/>
Item no	Description					Outcome <small>(Use codes above, provide additional comment where appropriate. C1, C2 and C3 coded items to be recorded in Section K of the Condition Report)</small>	Further investigation required? (YES / NO)				
5.0	FINAL CIRCUITS										
5.1	Identification of conductors (514.3.1)					✓					
5.2	Cables correctly supported throughout their run (522.8.5)					✓					
5.3	Condition of insulation of live parts (416.1)					✓					
5.4	Non-sheathed cables protected by enclosure in conduit, duct or trunking (521.10.1) • To include the integrity of conduit and trunking systems (metallic and plastic)					✓					
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)					✓					
5.6	Co-ordination between conductors and overload protective devices (433.1; 533.2.1)					✓					
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)					✓					
5.8	Presence and adequacy of circuit protective conductors (411.3.1.1; Section 543.1)					✓					
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)					✓					
5.10	Concealed cables installed in prescribed zones (see Section D Extent and limitations) (522.6.101)					Lim					
5.11	Concealed cables incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage from nails, screws and the like (see Section D: Extent and limitations) (522.6.101, 522.6.103)					✓					
5.12	Provision of additional protection by RCD not exceeding 30 mA: • For all socket-outlets of rating 20 A or less provided for use by ordinary persons unless an exception is permitted (411.3.3) • For supply to mobile equipment not exceeding 32 A rating for use outdoors (411.3.3) • For cables concealed in walls or partitions (522.6.102; 522.6.103)					C3 C3 C3					
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)					✓					
5.14	Band II cables segregated / separated from Band I cables (528.1)					Lim					
5.15	Cables segregated / separated from communications cabling (528.2)					Lim					
5.16	Cables segregated / separated from non-electrical services (528.3)					Lim					
5.17	Termination of cables at enclosures – indicate extent of sampling in Section D of the report (Section 526) • Connections soundly made and under no undue strain (526.6) • No basic insulation of a conductor visible outside enclosure (526.8) • Connections of live conductors adequately enclosed (526.5) • Adequately connected at point of entry to enclosure (glands, bushes, etc.) (522.8.5)					✓ ✓ ✓ ✓					
5.18	Condition of accessories including socket-outlets, switches and joint boxes (621.2(iii))					C1					
5.19	Suitability of accessories for external influences (512.2)					✓					
6.0	LOCATION(S) CONTAINING A BATH OR SHOWER										
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)					C3					
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)					✓					
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)					✓					
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2008 (701.415.2)					✓					
6.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1 (701.512.3)					N/A					
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)					✓					
6.7	Suitability of equipment for installation in a particular zone (701.512.3)					✓					
6.8	Suitability of current-using equipment for a particular position within the location (701.55)					✓					
7.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS										
7.1	List all other special installations or locations present, if any (record separately the results of particular inspections applied).					N/A					

Tested by:

Name (CAPITALS) A. MOFFATT

Signature A. Moffatt

Date 11/9/14

SCHEDULE OF TEST RESULTS




Used as primary sheet

Used as continuation sheet



Sheet of



Part of the ECA Group

DB Reference no. MAIN SWITCH PAVEL BLOCK H
 Location Block H Ground Floor Supboard
 Zs at DB (Ω)
 I_{pf} at DB (kA)
 Correct polarity of supply confirmed **YES** / NO
 Phase sequence confirmed (where appropriate)

Details of circuits and/or installed equipment vulnerable to damage when testing
 Continuity
 Insulation resistance
 Earth fault loop impedance
 RCD
 Earth electrode resistance

Details of test instruments used (state serial and/or asset numbers)
 Continuity F.W.K. 1651 96704
 Insulation resistance
 Earth fault loop impedance
 RCD
 Earth electrode resistance

Tested by: A. Moffatt
 Name (CAPITALS)
 Signature A. Moffatt Date 11/9/14

Test results

Circuit number	Ring final circuit continuity (Ω)			Continuity (Ω) (R ₁ + R ₂) or R ₂	Insulation resistance (MΩ)		Polarity	Z _s (Ω)	RCD (ms)		Remarks (continue on a separate sheet if necessary)		
	r ₁ (line)	r _n (neutral)	r ₂ (cpc)		Live - Live	Live - E			@ 5V _n	@ 5V _n			
A	J	K	L	M	N	O	P	Q	R	S	T	U	V
111								✓	0	N/A	N/A	N/A	
112													
113													
211													
212													
213													
311													
312													
313													
411													
412													
413													
511													
512													
513													

Circuit details

Circuit number	Circuit description	BS (EN)	Overcurrent device				Conductor details		
			Type	Rating (A)	Breaking capacity (kA)	Reference method	Live (mm ²)	cpc (mm ²)	
A	B	C	D	E	F	G	H	I	
111	SPARE								
112									
113									
211	SPARE								
212									
213									
311	SPARE								
312									
313									
411	LANELOLD SALLY	60947-2	-	25	25	N/A	16	16	
412									
413									
511	DB FLAT HI	60947-1	-	63	25	N/A	16	16	
512									
513									
514	DB H4	60947-2	-	63	25	N/A	16	16	
515									
516									

* Where there are no spurs connected to a ring final circuit this value is also the (R₁ + R₂) of the circuit.

DETAILS AT DISTRIBUTION BOARD (DB) / CONSUMER UNIT (CU)

Page of

CERTIFICATE NO.

Inspected and tested by: (Print and sign)

Location: Date:

Designation: MAIN Switch Panel Block H CONTD

System Characteristics

System type: TNS TT

(Tick relevant box(es))

Voltage rating: V Current rating [I_n]: A

(If) RCD: mA Operation time (at I_{Δn}): ms

DB/CU supplied from:

Measured impedance at dis. board/ consumer unit Z_o/Z_s*: Ω

Supply polarity confirmed:

Make: BS (EN):

Signature:

Equipment vulnerable to testing:

Supply Protective Device Details BS (EN): Current rating [I_n]: A (If) RCD: I_{Δn}: mA Operating time at I_{Δn}: ms

CIRCUIT DETAILS

TEST RESULTS

Circuit number	Circuit description	Number of points served	Overcurrent device				Conductor details			Ring final circuit continuity (Ω)			Continuity (At least one column to be completed)	Insulation Resistance (MΩ)	To earth	Max measured Z _s (Ω)	I _{Δn} (mA)	RCD (ms)	Test Button operation ✓	Remarks (continue on a separate sheet if necessary)
			BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Reference method	Live (mm²)	Cpc (mm²)	Operating current, I _{Δn} (mA)	r ₁ (line)	r _n (neutral)								
611	DB HS	1	63	MIA	63	85	MIA	16	16		0.06	> 200	> 200	✓	✓	0.12	MIA	N/A	N/A	
612																				
613																				
711	SPARK																			
712																				
713																				
811	SPARK																			
812																				
813																				
911	SPARK																			
912																				

TEST INSTRUMENTS USED	Make	Model	Serial Number	Multi-Function	Insulation Resistance	Continuity	Earth electrode resistance	Earth fault loop impedance	RCD

DETAILS AT DISTRIBUTION BOARD (DB)/CONSUMER UNIT (CU)

CERT REPORTING

Location: Date: Inspected and tested by: (Print and sign)

Designation: MAIN Switch Panel Block 4 CONTR

Name: Signature: Equipment vulnerable to testing:

System type: TNS-C TNS TT (Tick relevant box(es))

Supply polarity confirmed: BS (EN): Voltage rating: V Current rating (I_n): A

(If) RCD: mA Operation time (at I_{Δn}): ms

DB/CU supplied from: Measured impedance at dis. board/ consumer unit Z_e/Z_s*: Ω

Current rating (I_n): A (If) RCD: I_{Δn}: mA Operating time at I_{Δn}: ms

CIRCUIT DETAILS

TEST RESULTS

Circuit number	Circuit description	Number of points served	Overcurrent device				Conductor details			Ring final circuit continuity (Ω)			Insulation Resistance (MΩ)	Continuity (Ω)	Max measured Z _e (Ω)	RCD (ms)		Remarks (continue on a separate sheet if necessary)
			BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Reference method	Lve (mm ²)	Cpc (mm ²)	Operating current, I _{Δn} (mA)	R ₁ (line)	R ₂ (neutral)				R _e (cpc)	(R ₁ + R ₂)	
101	DB WARDENS FLAT	1	60947-2	MIA	32	25	MIA	16	16	MIA	0.09	>200	>200	>200	0.15	N/A	N/A	N/A
102	SPARE	1	60947-1	MIA	63	25	-	-	-	-	-	-	-	-	-	-	-	-
103	SPARE	1	60947-2	MIA	63	25	-	-	-	-	-	-	-	-	-	-	-	-
111	DB H 3	1	60947-2	MIA	63	25	16	16	16	16	0.03	>200	>200	>200	0.09	0.09	0.09	0.09
112	SPARE	1	60947-2	MIA	63	25	16	16	16	16	0.09	>200	>200	>200	0.14	0.14	0.14	0.14
121	DB H 2	1	60947-2	MIA	63	25	16	16	16	16	0.09	>200	>200	>200	0.14	0.14	0.14	0.14
122	SPARE	1	60947-2	MIA	63	25	16	16	16	16	0.09	>200	>200	>200	0.14	0.14	0.14	0.14
123	SPARE	1	60947-2	MIA	63	25	16	16	16	16	0.09	>200	>200	>200	0.14	0.14	0.14	0.14

DETAILS AT DISTRIBUTION BOARD (DB)/CONSUMER UNIT (CU)

Page of

CERT/REPORTING

Location: GROUND FLOOR UNDER STAIRS BLOCK H Date: 11/9/14

Inspected and tested by: (Print and sign)
Name: A. MOFFATT

Designation: LANALOROS

Signature: A. Moffatt

System Characteristics

System type: TNS TT TN-C-S
(Tick relevant box(es))

Equipment vulnerable to testing:

Supply polarity confirmed: **Main Switch**
Make: CLAS TRC

BS (EN): 60947-3

Voltage rating: 130 V Current rating (I_n): 100 A

(If) RCD: M/A mA Operation time (at I_{Δn}):

1 φ 2.4 kA

DB/CU supplied from: MAIN SWITCH PANEL

3 φ

Ground Floor Under Stairs Circuit 3L3

Measured impedance at dis. board/ consumer unit Z₀/Z_s: 0.07 Ω

(If) RCD: I_{Δn}: N/A mA Operating time at I_{Δn}:

Supply Protective Device Details

BS (EN): 60947-3 Current rating (I_n): 25 A

CIRCUIT DETAILS

TEST RESULTS

Circuit number	Circuit description	Overcurrent device				Conductor details			Ring final circuit continuity (Ω)			Insulation Resistance (MΩ)		Continuity (As least one column to be completed)	Max measured Z _e (Ω)	RCD (ms)		Remarks (continue on a separate sheet if necessary)
		BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Reference method	Lve (mm ²)	Cpc (mm ²)	Operating current, I _{Δn} (mA)	r ₁ (line)	r ₂ (neutral)	r _e (cpc)	Live-Live			Live-Earth	① I _{Δn}	
1	SMOKE VENT	60998	B	16	10	N/A	2.5	1.5	M/A	0.63	✓	LIM	>200	✓	0.70	M/A	N/A	
2	FIRE ALARM			16			2.5	1.5		0.28	✓	LIM	>200	✓	0.24			
3	DOOR ENTRY			16			2.5	1.5		0.20	✓	LIM	>200	✓	0.27			
4	SOCKETS STAIR WELLS			32			2.5	1.5		0.44	✓	>200	>200	✓	0.46			
5	CAMERAS			10			2.5	1.5		0.30	✓	LIM	>200	✓	0.37			
6	IMMERSION HEAT CONTRACTORS 2			6			1.5	1.0		0.13	✓	LIM	>200	✓	0.20			
7	LIGHTS STAIR WELLS			6			1.5	1.0		2.39	✓	LIM	147	✓	2.46			
8	LIGHTS OUTSIDE			6			1.5	1.0		1.01	✓	LIM	107	✓	1.08			

TEST INSTRUMENTS USED	Make/Model	Serial Number
Multi-function	Fluke 6	960964
Insulation Resistance		
Continuity		
Earth electrode resistance		
Earth fault loop impedance		
RCD		

SCHEDULES FOR RECORDING INSPECTION AND CIRCUIT DETAILS/TEST RESULTS

INSPECTION EXIST

(A) BOTH BASIC AND FAULT PROTECTION
SELV / PELV*

(B) BASIC PROTECTION
Double or reinforced insulation*

(C) FAULT PROTECTION
Automatic disconnection of supply

(D) ADDITIONAL PROTECTION
Presence of supplementary bonding conductors

(E) PREVENTION OF CONTACT WITH LIVE PARTS
(a) Proximity of non-electrical services and other influences
(b) Segregation of safety and non-safety circuits (Band I & Band II etc.)

(F) IDENTIFICATION
(a) Presence of diagrams, instructions, circuit charts and similar information
(b) Presence of danger notices and other warning notices
(c) Labeling of protective devices, switches and terminals
(d) Identification of conductors

(G) CABLES AND CONDUITS
(a) Selection of conductors for current-carrying capacity and voltage drop
(b) Erection methods
(c) Cables incorporating armour or sheath, or routed within a wiring system, or otherwise adequately protected against nails, screws and the like
(d) Routing of cables in prescribed zones
(e) Additional protection by suitably rated RCD for cables concealed in walls (where not under the supervision of a skilled or instructed person)
(f) Connection of conductors
(g) Presence of fire barriers and similar for protection against thermal effects

(H) GENERAL
(a) Presence and correct location of appropriate devices for isolation and switching
(b) Adequacy of access to switchgear and other equipment
(c) Particular protective measures for special installations or locations
(d) Connection of single-pole devices for protection or switching in the conductor(s) only
(e) Correct connection of accessories and equipment
(f) Presence of undervoltage protective devices
(g) Selection of equipment and protective measures appropriate to external influences
(h) Selection of appropriate functional switching devices

Installation Address: **Block H Room 2 WARDENS KEM**

Designation of switchgear: **DBS WARDENS FLAT**

System Characteristics:
System Type: **TNS** IT
(Tick relevant box(es))
Fault Level(s):
1 ϕ **1.7** kA
3 ϕ **0.15** kA

Measured impedance at dis. board/consumer unit Z_s : **0.15** Ω

Supply Protective Device (Type): **60893**

Inspected and tested by: **PLM**

Equipment vulnerable to testing: **Equipment vulnerable to testing**

Comments: **Equipment vulnerable to testing**

TEST INSTRUMENTS USED

MAKE	MODEL	FUNCTION	MAKE	MODEL	FUNCTION
FLUKE	1651	Insulation resistance	FLUKE	1651	Insulation resistance
FLUKE	1651	Earth electrode resistance	FLUKE	1651	Earth electrode resistance
FLUKE	1651	Earth fault loop impedance	FLUKE	1651	Earth fault loop impedance

In addition to these the following notations may be used when reporting on existing installations:

NOTATION	MEANING
N/A	Indicates an inspection is not applicable to a particular item of equipment, etc.
UM	Indicates that exceptional measurement was used with the reason for doing the work prevented the inspection being carried out

Operating time at I_n kA: **ms**

(H) RCD: I_n mA: **32** A

BS (EN): **6047-2** Current Rating (I_n): **32** A

BS (EN): **6047-3** BS (EN): **6047-3**

Make: **CHRISTIE** Voltage Rating: **240** V Current Rating (I_n): **100** A

(H) RCD: **ms** Operation time (at I_n): **ms**

DB/OU supplied from: **Main Switch**

Main Switch Power Block

CIRCUIT DETAILS AND TEST RESULTS

Number of ways	Circuit description	Circuit conductors (mm ²)		Over-current protective devices		RCD		Circuit impedances (Ω)		Insulation resistance (MΩ)		Maximum measured earth fault loop impedance (Z _s)	Polarity (V)	RCD operating times (ms)	
		L	N	Type	Rating (A)	Tripping current (mA)	Operating current (mA)	Between live conductors	Live conductors to Earth	R ₁	R ₂			R ₃	at I _n
1	HEATING	2.5	1.5	B	16	16	16	23	24	28	55	0.12	✓	0.6	0.6
2	HEATING	2.5	1.5	B	16	16	16	18	18	29	1.10	✓	0.47	1	1
3	RING CIRCUIT	2.5	1.5	B	32	32	32	44	45	28	1.27	✓	0.86	1	1
4	COOKER	6.0	2.5	B	32	32	32	1.5	1.0		1.21	✓	0.22	1	1
5	LIGHTS	1.5	1.0	B	10	10	10				1.22	✓	0.22	1	1
6	IMMER SIG	2.5	1.0	B	16	16	16								
7	IMMER SIOE	2.5	1.0	B	16	16	16								
8	SPACE	2.5	1.0	B	16	16	16								

Can be used in conjunction with TD16F for Observations and Comments

* delete as appropriate

© Signal International Ltd

DETAILS AT DISTRIBUTION BOARD (DB)/CONSUMER UNIT (CU)

CERTIFY REPORTING

Location: **Block 4, Ground Floor H1-6 Kitchen Cupboards** Date: **11/9/14**

Inspected and tested by: (Print and sign)
A. Moffatt

Designation: **DB H1**

Signature: **A. Moffatt**

System Characteristics

System type: TN-S TT TNC-S

Main Switch

Supply polarity confirmed:

Make: **CRAIG** BS (EN): **60347-2**

Voltage rating: **415** V Current rating (I_n): **100** A

(If) RCD: **N/A** mA Operation time (at I_{Δn}): **—** ms

DB/CU supplied from: **Block 4 Ground Floor**

(NBSA Stairs Cupboard Main Panel Circuit 4473)

Measured impedance at dis. board/ consumer unit Z₀/Z_s * : **0.14** Ω

BS (EN): **60347-2** Current rating (I_n): **63** A (If) RCD: **N/A** mA Operating time at I_{Δn}: **—** ms

CIRCUIT DETAILS

TEST RESULTS

Circuit number	Circuit description	Number of points served	Overcurrent device			Conductor details			Ring final circuit continuity (Ω)			Insulation Resistance (MΩ)	Continuity (Ω) (At least one column to be completed)	Max measured Z _s (Ω)	RCD (ms)		Remarks (continue on a separate sheet if necessary)
			BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Reference method	Live (mm ²)	Cpc (mm ²)	Operating current, I _{Δn} (mA)	R ₁ (line)				R ₂ (neutral)	R ₃ (cpc)	
101	COOKER H1-6	1	60398	B	32	10	N/A	6.0	2.5	N/A	>200	>200	N/A	N/A	N/A	N/A	
102	SOCKETS H4-6	7			32			2.5	1.5		>200	>200	0.61	0.73			
103	IMMERSION + PUMP	2			16			2.5	1.5		>200	>200	0.10	0.24			
201	LIGHTS H1+2	25			10			1.5	1.0		414	713	0.91	1.06			
202	COOKER H1-6	1			32			6.0	2.5		>200	>200	0.32	0.46			
203	IMMERSION HEATER	1			16			2.5	1.5		>200	>200	0.09	0.22			
301	SOCKETS KITCHEN + ROOMS 1-3	10			32			2.5	1.5		414	109	0.33	0.46			
302	HEATING ROOMS	4			20			2.5	1.5		>200	>200	0.16	0.30			
303	Socket RISER CUPBOARD	1			16			1.5	1.0		414	200	0.65	0.79			
401	LIGHTS KITCHEN H3	13			10			1.5	1.0		414	200	0.32	0.46			
402	HEATING KITCHEN	4			20			2.5	1.5		414	86.9	0.32	0.46			

TEST INSTRUMENTS USED	Make/Model	Serial Number	Fluke (65)	Multi-Function	Insulation Resistance	Continuity	Earth electrode resistance	Earth fault loop impedance	RCD
	Fluke 65	160904							

DETAILS AT DISTRIBUTION BOARD (DB) / CONSUMER UNIT (CU)

Location: **Block # H7-12 KITCHEN CUPBOARD** Date: **11/9/14**
 Designation: **Dist board H2**
 Respected and tested by: (Print and sign)
 Name: **A. McFEAT**
 Signature: **A. McFEAT**

System Characteristics

System type: TNS TT TNCS
 (Tick relevant box(es))

Equipment vulnerable to testing:

Supply polarity confirmed:

Make: **CHARTER** BS (EN): **60987-3**
 Voltage rating: **415** V Current rating (I_n): **100** A
 (If) RCD: **N/A** mA Operation time (at I_{Δn}):ms

DB/CU supplied from: **Block # Ground Floor**
Cupboard MAIN PENAL CIRCUIT 12, 13, 14, 15

Measured impedance at dis. board/consumer unit Z_e/Z_s: **0.14** Ω

Supply Protective Device Details BS (EN): **60987-3** Current rating (I_n): **63** A (If) RCD: I_{Δn}: **N/A** mA Operating time at I_{Δn}: ms

CIRCUIT DETAILS										TEST RESULTS								
Circuit number	Circuit description	Number of points served	Overcurrent device			Conductor details			Ring final circuit continuity (Ω)			Insulation Resistance (MΩ)	Polarity	Max measured Z _s (Ω)	RCD (ms)		Remarks (continue on a separate sheet if necessary)	
			BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Reference method	Live (mm ²)	Cpc (mm ²)	R ₁ (line)	R ₂ (cpc)				Continuity (Ω) (At least one column to be completed)	@ I _{Δn}		@ 5 I _{Δn}
1L1	sockets H7-12	8	60898	B	32	10	N/A	2.5	1.5	0.49	0.46	0.26	>200	✓	0.54	N/A	N/A	
1L2	Lights Kitchen/corridor Rooms 11+12	17			110			1.5	1.0				4M	✓	1.23			
1L3	COOKER H7-12	1			32			6.0	2.5			0.47	>200	✓	0.61			
2L1	IMMERSION HEATER	1			16			2.5	1.5			0.09	>200	✓	0.23			
2L2	COOKER H7-12	1			32			6.0	2.5			0.82	>200	✓	0.96			
2L3	SPARS																	
3L1	Immersion + pump	2	60898	B	16	10	N/A	2.5	1.5			0.11	>200	✓	0.25			
3L2	Kitchen Kitchen/corridor sockets Rooms 11+12	8			32			2.5	1.5	0.62	0.62	0.80	4M	✓	0.42			
3L3	HEATING	4			20			2.5	1.5			0.42	4M	✓	0.57			
4L1	LIGHTS 7-10	20			10			1.5	1.0			0.77	4M	✓	0.91			
4L2	SPARS																	

DETAILS AT DISTRIBUTION BOARD (DB)/CONSUMER UNIT (CU)

CERT/REPORT NO. _____

Inspected and tested by: (Print and sign)

Name: _____

Date: _____

Location: _____

Signature: _____

Equipment vulnerable to testing: _____

Designation: D.I.S.T. BOARD H.2 C.O.T.D.

Supply polarity confirmed:

Make: _____

System type: TNS TT TN-S

Voltage rating: _____ V

(If) RCD: _____ mA

System Characteristics

Current rating (I_n): _____ A

Operating time at $I_{\Delta n}$: _____ ms

Fault level(s):

Continuity (Ω): _____

Insulation Resistance (M Ω): _____

1 ϕ kA
3 ϕ kA

Max measured Z_s (Ω): _____

Reference method: _____

Measured impedance at dis. board/consumer unit Z_0/Z_0^* : _____ Ω

Operating time at $I_{\Delta n}$: _____ ms

DB/CU supplied from: _____

Overcurrent device

BS (EN): _____

Rating (A): _____

6098 B 20 10

BS (EN): _____

Breaking capacity (kA): _____

4

Number of points served: _____

Circuit description: _____

4 HEATING
511 SPARE
512
513
611
612
613

Circuit details

Reference method

N/A 2-S

Conductor details

Live (mm²)

1.5

RCD (mA)

Operating current, $I_{\Delta n}$

N/A

Ring final circuit continuity (Ω)

R_1 (line)

0.47

Continuity (Ω) (At least one column to be completed)

$R_1 + R_2$

> 100

Insulation Resistance (M Ω)

Live-Live

7200

Max measured Z_s (Ω)

Test Button

0.61

RCD (ms)

$I_{\Delta n}$

N/A

Remarks (continue on a separate sheet if necessary)

Test Button

N/A

Earth electrode resistance

Continuity

Earth fault loop impedance

Installation resistance

Make

Model

Serial Number

Multi-function

TEST INSTRUMENTS USED

Make

Model

Serial Number

Multi-function

Installation resistance

Continuity

Earth electrode resistance

Earth fault loop impedance

RCD

Deviations from BS 7671: 2008 and further comments:

DETAILS AT DISTRIBUTION BOARD (DB)/CONSUMER UNIT (CU)

CERT/REPORTING

Location: Block H First Floor H 13-18 Kitchen cupboard Date: 11/9/14 Page of

Inspected and tested by: (Print and sign)
Name: A. Moffatt

Signature: A. Moffatt

Designation: DIST BOARD H 3

System Characteristics

System type: TNS TT TNCS

(Tick relevant boxes)
Fault level(s):
1 ϕ kA
3 ϕ kA

Supply polarity confirmed:

Make: CARABACK BS (EN): 60947-3

Voltage rating: 415 V Current rating (I_n): 100 A

(If) RCD: N/A mA Operation time (at $I_{\Delta n}$): ms

DB/CU supplied from: Block H Ground Floor

Cupboard MAIN SWITCH PANEL CIRCUIT 11,12,13

Measured impedance at dis. board/consumer unit Z_0/Z_0^* : 0.09 Ω

(If) RCD: $I_{\Delta n}$: N/A mA Operating time at $I_{\Delta n}$: ms

CIRCUIT DETAILS

Supply Protective Device Details BS (EN): 60947-1 Current rating (I_n): 63 A

TEST RESULTS

Circuit number	Circuit description	Number of points served	Overcurrent device			Conductor details			Ring final circuit continuity (Ω)			Continuity (Ω) (At least one column to be completed)		Insulation Resistance (M Ω)	Leakage $I_{\Delta n}$ (mA)	RCD (ms)	Remarks (continue on a separate sheet if necessary)	
			BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Reference method	Lve (mm ²)	Cpc (mm ²)	Operating current, $I_{\Delta n}$	R_1 (line)	R_2 (cpc)	$R_1 + R_2$					R_1 (neutral)
101	SOCKETS KITCHEN ROOM 13-18	10	60988	B	32	10	N/A	2.5	1.5	1.5	0.40	0.40	0.26	0.31	1.1M	>200	N/A	N/A
102	IMMERSION HEATER	1			16			2.5	1.5		0.15				>200			
103	SOCKETS CORRIDOR H16-18	7			32			2.5	1.5		0.22	0.24	0.22		>200			
201	COOKER	1			32			6.0	2.5		0.22				>200			
202	IMMERSION/PUMP	2			16			2.5	1.5		0.18				>200			
203	LIGHTS ROOMS 13-18	20			10			1.5	1.0		0.97				1.1M			
301	LIGHTS KITCHEN ROOMS 16-18	18			10			1.5	1.0		0.72				1.1M			
302	COOKER	1			32			6.0	2.5		0.19				>200			
303	HEATING	4			20			2.5	1.5		0.71				1.1M			
401	SPARKS																	
402	SPARKS																	

TEST INSTRUMENTS USED	Make (S)	Model	Serial Number	Multi-function	Fluke (S)	Insulation resistance	Continuity	Earth electrode resistance	Earth fault loop impedance	RCD
			4601051							

DETAILS AT DISTRIBUTION BOARD (DB) / CONSUMER UNIT (CU)

CERT REPORTING

Page of

Inspected and tested by: (Print and sign)

Location: Date:

Designation: DIST 60A/0 H3 CONT.0

System Characteristics

System type: TN-C TN-S TT

(Tick relevant box(es))

Fault level(s):

1 ϕ kA

3 ϕ kA

Measured impedance at dis. board/consumer unit Z_o/Z_s^* : Ω

Main Switch

Supply polarity confirmed:

Make: BS (EN):

Voltage rating: V Current rating (I_n): A

(If) RCD: mA Operation time (at $I_{\Delta n}$): ms

DB/CU supplied from:

Name:
Signature:

Equipment vulnerable to testing:

Supply/Protective Device Details

BS (EN):

Current rating (I_n): A

(If) RCD: $I_{\Delta n}$: mA

Operating time at $I_{\Delta n}$: ms

CIRCUIT DETAILS

Circuit number	Circuit description	Number of points served	Overcurrent device			Conductor details			Ring final circuit continuity (Ω)			Continuity (Ω) <small>(At least one column to be completed)</small>	Insulation Resistance (M Ω)	Polarity	Max measured Z_s (Ω)	RCD (ms)		Remarks (continue on a separate sheet if necessary)
			BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Reference method	Lve (mm ²)	Cpc (mm ²)	$R_1 + R_2$	R_2 (cpc)					R_n (neutral)	R_e (line)	
403	HEATING	4	60191	B	20	10	M/A	2.5	1.5	M/A	0.97	Lve-Lve	✓		1.06	M/A	M/A	
54	SPANS																	
503																		
603																		
602																		
603																		

TEST RESULTS

TEST INSTRUMENTS USED	Make (Model)	Serial Number	Multi-function	Insulation resistance	Continuity	Earth electrode resistance	Earth fault loop impedance	RCD

DETAILS AT DISTRIBUTION BOARD (DB)/CONSUMER UNIT (CU)

CERTIFICATE NO.

Location: Block H Second Floor H19-24 Kitchen Date: 12/9/14 Page of

Designation: DIST BOARD H4

Inspected and tested by: (Print and sign)
Name: A. MUFFAT
Signature: A. Muffat

System Characteristics

System type: TNS TT TN-C-S

(Tick relevant box(es))

Supply polarity confirmed:

Make: CAA8766 BS (EN): 60947-3

Voltage rating: 415 V Current rating (I_n): 100 A

(If) RCD: N/A mA Operation time (at I_{Δn}): — ms

DB/CU supplied from: Block H Ground Floor

Capacitance: 0.14 Ω

DB/CU supplied from: Block H Ground Floor

Capacitance: 51.2, 3

Measured impedance at dis. board/consumer unit Z_e/Z_s: 0.14 Ω

Supply Protective Device Details BS (EN): 60947-3 Current rating (I_n): 63 A (If) RCD: N/A mA Operating time at I_{Δn}: — ms

CIRCUIT DETAILS

Circuit number	Circuit description	Number of points served	Overcurrent device			Conductor details			Ring final circuit continuity (Ω)			Continuity (As least one column to be completed)	Insulation Resistance (MΩ)	RCD (ms)	Remarks (continue on a separate sheet if necessary)
			BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Reference method	Lve (mm ²)	Cpc (mm ²)	R _s (line)	R _s (neutral)				
111	HEATING	4	60398	B	32	10	N/A	2.5	1.5	N/A	N/A	>200	>200	N/A	
112	COOKER H19-24	1			32			6.0	2.5			>200	>200		
113	SOCKETS ROOMS	8			16			2.5	1.5	0.52	0.52	0.23	0.20		
211	IMMERSION HEATER	1			32			2.5	1.5	0.52	0.57	0.41	0.23		
212	SOCKETS KITCHEN/LOUNGS	9			16			2.5	1.5			>200	>200		
213	IMMERSION + PUMP	2			16			2.5	1.5			>200	>200		
311	Spare														
312	COOKER H19-24	1	60398	B	32	10		6.0	2.5			>200	>200		
313	LIGHTS KITCHEN ROOMS	18			16			1.5	1.0			>200	>200		
411	HEATING	4			16			2.5	1.5			>200	>200		
412	VAUCSO				16							>200	>200		

TEST INSTRUMENTS USED	Make	Model	Serial Number	Earth electrode resistance	Continuity	Earth fault loop impedance	RCD

DETAILS AT DISTRIBUTION BOARD (DB)/CONSUMER UNIT (CU)

Page of



Location: Date: Inspected and tested by: (Print and sign)

Designation: **DIST BOARD 4** Name: Signature:

System Characteristics

System type: TNS- TN-S TT

(Tick relevant box(es))

Fault level(s):
 1 φ kA
 3 φ kA

Measured impedance at dis. board/consumer unit Z_0/Z_s^* : Ω

Main Switch Supply polarity confirmed:

Make: BS (EN):
 Voltage rating: V Current rating (I_n): A
 (If) RCD: mA Operation time (at I_{Δn}): ms
 DB/CU supplied from:

Supply Protective Device Details BS (EN): Current rating (I_n): A (If) RCD: I_{Δn}: mA Operating time at I_{Δn}: ms

CIRCUIT DETAILS

Circuit number	Circuit description	Number of points served	Overcurrent device			Conductor details			Ring final circuit continuity (Ω)			Insulation Resistance (MΩ)	Max measured Z _s (Ω)	RCD (ms)		Remarks (continue on a separate sheet if necessary)	
			BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Reference method	Lve (mm ²)	Cpc (mm ²)	RCD current, I _{Δn}	Continuity (Ω) (At least one column to be completed)			Cont. (Ω)	Test Button operation ✓		@ I _{Δn}
403	LIVES ROOMS x4	20	60998	B	10	10	N/A	1.5	1.0								
501	SPARE																
502																	
503																	
601																	
602																	
603																	

TEST RESULTS

TEST INSTRUMENTS USED	Serial Number	Make/Model	Multipoint functions	Insulation Resistance	Continuity	Earth electrode resistance	Earth fault loop impedance	RCD

Deviations from BS 7671, 2008, and further comments:

DETAILS AT DISTRIBUTION BOARD (DB)/CONSUMER UNIT (CU)

CERTIFY REPORTING

Location: **Block H Second Floor 425-30 Kitchen Cupboard** Date: **12/9/14** Page **1** of **1**

inspected and tested by: (Print and sign)
Name: **A. MORTON**

Designation: **Dist Board H 5**

Signature: **A. Morton**

System Characteristics

System type: TNS TT TN-C-S (Tick relevant box(es))

Fault level(s): 1 ϕ kA

3 ϕ kA

Supply polarity confirmed:

Make: **CRAB TRACK** BS (EN): **60947-3**

Voltage rating: **415** V Current rating (I_n): **100** A

(If) RCD: **N/A** mA Operation time (at I_{Δn}): ms

DB/CU supplied from: **Block H Ground Floor**

CUPRAKO, MAIN SWITCH PANEL CIRCUIT 60947-3

Measured impedance at dis. board/consumer unit Z_e/Z₀: **0.12** Ω

Supply Protective Device Details BS (EN): **60947-2** Current rating (I_n): **63** A (If) RCD: I_{Δn}: **N/A** mA Operating time at I_{Δn}: ms

CIRCUIT DETAILS

Circuit number	Circuit description	Number of points served	Overcurrent device			Conductor details			Ring final circuit continuity			Continuity (at least one column to be completed)		Insulation Resistance (M Ω)	Lev-It	RCD (ms)	Remarks (continue on a separate sheet if necessary)
			Type	Rating (A)	Breaking capacity (kA)	Reference method	Live (mm ²)	Cpc (mm ²)	Operating current I _n	R _s (line)	R _s (neutral)	R _s (cpc)	R _s (R ₁ + R ₂)				
1L1	SPARE																
1L2	HEATING ROOM 427	3	B	20	10	N/A	2.5	1.5			0.49		LIM	>100			
1L3	COOKER 25-30	1		32			6.0	2.5			0.27		>200	>200			
2L1	Water Heater	1		16			2.5	1.5			0.10		>200	>200			
2L2	Water Heater Pump	2		32			2.5	1.5			0.14		>200	>200			
2L3	COOKER 25-30	1		32			6.0	2.5			0.31		>200	>200			
3L1	Sockets 25, 16, 20, 30	10		32			2.5	1.5			0.51	0.32	LIM	>200			
3L2	SPARE																
3L3	Sockets Kitchen	6	B	32	10	N/A	2.5	1.5			0.39	0.71	LIM	>100			
4L1	LIVING ROOMS	20		10			1.5	1.0			0.74		LIM	>200			
4L2	HEATING	4		20			2.5	1.5			0.45		LIM	>100			

TEST INSTRUMENTS USED	Make (Model)	Serial Number	Multi-Function	Fluke (kV)	Insulation Resistance	Continuity	Earth electrode Resistance	Earth fault loop Impedance	RCD

DETAILS AT DISTRIBUTION BOARD (DB)/CONSUMER UNIT (CU)

CERT REPORT NO.

Page of

Location: Date:

Inspected and tested by: (Print and sign)
 Name:
 Signature:

Designation: *DIST BOARD HS CONTD*

System Characteristics

System type: TNS-S TT TN-C-S
 (Tick relevant box(es))

Supply polarity confirmed:

Make: BS (EN):

Voltage rating: V Current rating (I_n): A

(If) RCD: mA Operation time (at I_{Δn}): ms

DB/CU supplied from:

Measured impedance at dis. board/consumer unit Z_e/Z₀*: Ω

(If) RCD: I_{Δn}: mA Operating time at I_{Δn}: ms

CIRCUIT DETAILS

Circuit number	Circuit description	Overcurrent device			Conductor details			Ring final circuit continuity (Ω)			Continuity (As least one column to be completed)	Insulation Resistance (MΩ)	Polarity	Max measured Z _e (Ω)	RCD (ms)		Remarks (continue on a separate sheet if necessary)
		BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Reference method	Lve (mm ²)	Cpc (mm ²)	Operating current, I _{Δn} (mA)	R ₁ (line)					R ₂ (neutral)	R ₃ (cpc)	
4L3	Lights kitchen/bathroom	15	6	10	10	N/A	15	1.0				✓	0.89	N/A	N/A	N/A	
5L1	SPACE																
5L2																	
5L3																	
6L1																	
6L2																	
6L3																	

TEST INSTRUMENTS USED

Make: Model: Serial Number:

Insulation resistance

.....

Continuity

.....

Earth electrode resistance

.....

Earth fault loop impedance

.....

RCD

.....