Gas Installation	ECV		SATISFACTORY	VEO	SATISFACTORY TIGHTNESS	\	EQUIPOTENTIAL BONDING	\ \ \
Pipe work	ACCESSIBLE	YES	VISUAL	YES	TEST	YES	SATISFACTORY	YES
,	7.0000.00.		1.007.1				0	

	APPLIANCE DETAILS					FLUE TESTS			INSPECTION DETAILS								
#	Location	Make	Model	Туре	Flue type OF/RS/FL	Operating pressure in Mbar or heat input kW/h or Btu/h	Safety device(s) correct operation	Spillage Test	Smoke pellet flue flow test	Combustion analyser reading (if applicable)	Satisfactory termination	Flue visual condition	Adequate ventilation	Landlord's appliance	Inspected	Appliance serviced	Appliance Safe to Use
1	Kitchen	Glowworm	Ultracom	Boiler	RS	15 KW/h	Yes	N/A	N/A	000.7	Yes	Pass	YES	YES	YES	YES	YES
2	Kitchen	Cannon	Range	Cooker	OF	20 MBar	Yes	N/A	N/A	0	Yes	Pass	YES	YES	YES	NO	YES

De	staile of Faulte	Warning Notice Issued				
1	None	NO				
2	None	NO				
		·				

Comments	Appliance Tested:	2
None	Issued by:	Men.
	Received by:	Me
	Next Gas Inspection Due:	17/08/2017