

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

**REGISTERED BUSINESS DETAILS** Reg No: 127884

Gas Engineer: Carl Bodley

Gas Safe registered engineer No:

Company: Carl Bodley

Address: 30 Bransford, Couer  
Wolverhampton

Postcode: WV9 5DZ Tel: 07860680631

**INSPECTION/INSTALLATION ADDRESS**

Name & Title: Mr M Burns

Address: 13 Newhamper Rd West  
Wolverhampton

Postcode: WV6 0RY Tel:

I certify that I carried out inspections on the appliances detailed below.

Signed: [Signature] Inspection Date: 4.9.18

**LANDLORD (OR AGENT) NAME & ADDRESS** (if applicable)

Name & Title:

Address:

Postcode: Tel:

	APPLIANCE DETAILS						FLUE TESTS				INSPECTION DETAILS					
	Location	Make and Model	Type	Flue Type OF/RS/FL	Operating pressure in mbar or heat input kW/h or Btu/h	Safety device(s) correct operation Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet flue flow test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance Yes/No/NA	Inspected Yes/No	Appliance serviced Yes/No
1	<u>Kuon</u>	<u>Worcester 25SL</u>	<u>Combi</u>	<u>RS</u>	<u>205mb</u>	<u>yes</u>	<u>N/A</u>	<u>N/A</u>	<u>0010</u>	<u>0008</u>	<u>yes</u>	<u>Pass</u>	<u>yes</u>	<u>yes</u>	<u>yes</u>	<u>yes</u>
2																
3																
4																
5																

Gas Installation Pipework: Satisfactory Visual Inspection: Yes  No  Emergency Control Accessible: Yes  No  Satisfactory Gas Tightness Test: Yes  No  Equipotential Bonding Satisfactory: Yes  No

	GIVE DETAILS OF ANY FAULTS	RECTIFICATION WORK CARRIED OUT	WARNING NOTICE ISSUED	WARNING TAG or STICKER FIXED
			Yes/No/NA	Yes/No/NA
1				
2				
3				
4				
5				

Audible CO Alarms: Approved CO Alarms Fitted: Yes  No  N/A  Are CO Alarms in Date: Yes  No  N/A  Testing of CO Alarms Satisfactory: Yes  No  N/A  Smoke Alarms Fitted: Yes  No  N/A

Number of appliances tested: 1 **NEXT GAS SAFETY CHECK MUST BE CARRIED OUT WITHIN 12 MONTHS**

This record is issued by: Signed: [Signature] Print Name: CARL BODLEY Date: 4.9.18

Received on behalf of the Landlord/Home Owner: Signed: [Signature] Tenant/Agent/Landlord/Home Owner (Delete as applicable) Date: 4.9.18