



This safety certificate is an important and valuable document which should be retained for future reference

This certificate is not valid if the serial number has been defaced or altered DCP6/ 0306537

# DOMESTIC ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations by a Registered Domestic Installer registered with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZK

IRN/ [ ] Installer's Reference Number

## DETAILS OF THE CLIENT

Client and address  
PETE MARSHALL  
87 NEWCASTLE STREET,  
SILVERDALE,  
NEWCASTLE-U-LYME,  
STAFFORDSHIRE.  
Postcode ST5 6PL

## ADDRESS OF THE INSTALLATION

Installation address  
89 NEWCASTLE STREET,  
SILVERDALE,  
NEWCASTLE-U-LYME,  
STAFFORDSHIRE.  
Postcode ST5 6PL

## DETAILS OF THE INSTALLATION

Extent of the installation work covered by this certificate  
New Consumer Unit, New Double SGT BY MAINS, 3x Smoke Detectors and New Earthing to Gas + Water Services. EXISTING FIXED WIRING TESTED

The installation is  
New   
An addition   
An alteration

## DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I, being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671, 2008 amended to 2016 (date) except for the departures, if any, detailed as follows:  
Details of departures from BS 7671, as amended (Regulations 120.3, 133.5)

None.

The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the DESIGN, the CONSTRUCTION and the INSPECTION AND TESTING of the installation

Signature: A. Ashley Name (CAPITALS) AARON ASHLEY. Date 10.1.18

The results of the inspection and testing reviewed by the Qualified Supervisor

Signature: A. Ashley Name (CAPITALS) AARON ASHLEY. Date 10.1.18

## PARTICULARS OF THE REGISTERED DOMESTIC INSTALLER

Trading title  
A. A. ELECTRICAL SERVICES.  
Address  
2 MOORTHORNE CRESCENT,  
BRADWELL,  
NEWCASTLE-U-LYME  
STAFFORDSHIRE.  
Telephone No 07810576963 Postcode ST5 8HT.  
NICEIC Registration No (Essential information) 043721

## NEXT INSPECTION

§ Enter interval in terms of years, months or weeks, as appropriate

I RECOMMEND that this installation is further inspected and tested after an interval of not more than 5 YEARS

## COMMENTS ON EXISTING INSTALLATION

Note: Enter 'NONE' or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation

No C.P.C.s Present on Corridor, 3x Kitchen and Landing Switches  
No Isolator for Fan in Downstairs Toilet. Only Carried Out  
Ear Test L+N to Earth on 2x Ltg, + 2x SGT Circuits.

In the case of an alteration or additions see Section 633 of BS 7671

## SCHEDULE OF ADDITIONAL RECORDS\*

See attached schedule

None.

\* Where the electrical work to which this certificate relates includes the installation of a fire detection/ alarm system (or a part of such a system), this electrical safety certificate should be accompanied by the particular certificate for the system.

This certificate is based on the model forms shown in Appendix 6 of BS 7671.

Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (January 2015)

Please see the 'Notes for Recipients' on the reverse of this page.

Original (to the person ordering the work)