



# NAPIT Electrical Installation Condition Report

Requirements for Electrical Installations –  
BS 7671:2008 incorporating Amendment No.1, 2011  
[IET Wiring Regulations 17th Edition]

NA/EICR/001

53288

Page 1 of 7

**A Details of the installation**

Client <b>MR DAMIEN LINDLEY</b>	Installation (If different from client)
Address <b>65 WOODHOUSE HILL FARTOWN HUDDERSFIELD</b>	Address
Postcode	Postcode

**B Reason for producing this report** This form to be used only for reporting on the condition of an existing installation.

**5 YEARLY PERIODIC INSPECTION**

Date(s) on which the inspection and testing were carried out **28/4/14** to **30/4/14**

**C Details of the installation which is the subject of this report**

Description of premises  Domestic  Commercial  Industrial  Other (please state) \_\_\_\_\_

Estimated age of the wiring system **5** years

Evidence of alterations or addition  Yes  No  Not apparent If 'Yes', estimated \_\_\_\_\_ years

Records of installation available  Yes  No Records held by **N/A**

Date of last inspection **N/A /** Electrical Installation Certificate No. or previous Inspection Report No. \_\_\_\_\_

**D Extent and limitations of inspection and testing**

Extent of electrical installation covered by this report:

**All fixed wiring to lighting & power circuits**

Agreed limitations (See Regulations 634.2) Agreed with: **LANDLORD**

Operational limitations including the reasons (see page no \_\_\_\_\_ of \_\_\_\_\_)

The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2008 (IET Wiring Regulations), amended to **2014** (date)

It should be noted that cables concealed within the trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have **not** been inspected unless specifically agreed between the client and inspector prior to the inspection.

**E Summary of the condition of the installation**

General conditions of the Installation (in terms of safety)

**SATISFACTORY**

Overall assessment of the installation in terms of its suitability for continued use  SATISFACTORY  UNSATISFACTORY\*

\* An UNSATISFACTORY assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified

**F Recommendations**

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I / we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required'. Observations classified as 'Improvement recommended' (Code C3) should be given due consideration. Subject to the necessary remedial action being taken, I / we recommend that the installation is further inspected and tested by **30/4/19** (date)

**G Declaration**

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company <b>J W ELECTRICAL</b>	Inspected and tested by	Authorised for issue by
Membership No. <b>20139</b>	Name: <b>J WHITLES</b>	
Address <b>107 SWALLOW LANE GOLCAR</b>	Signature: <b>J WHITLES</b>	
Postcode <b>M07 4NB</b>	Position: <b>ELECTRICIAN</b>	
	Date: <b>30/4/14</b>	

**H Schedule(s)**

schedule(s) of inspection and  schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

© Copyright NAPIT July 2011

# NAPIT *Electrical Installation* Condition Report

## Guidance for recipients

This report is an important and valuable document which should be retained for future reference.

1. The purpose of this condition report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
2. The person ordering the Report should have received the original Report and the inspector should have retained a duplicate.
3. The original Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner /occupier with details of the condition of the electrical installation at the time the Report was issued.
4. Where the installation incorporates residual current devices (RCDs) there should be a notice at or near the devices stating that they should be tested quarterly. **For safety reasons it is important that these instructions are followed.**
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as C1 ("Danger Present"), **the safety of those using the installation is at risk**, and it is recommended that a competent person undertakes the necessary remedial work immediately.
8. For items classified in Section K as C2 ("Potentially Dangerous"), **the safety of those using the installation may be at risk** and it is recommended that a competent person undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section K that an observation requires further investigation the inspection has revealed an apparent deficiency which could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a competent person. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit / distribution board.



# NAPIT Electrical Installation Condition Report

Requirements for Electrical Installations -  
BS 7671:2008 incorporating Amendment No.1, 2011  
[IET Wiring Regulations 17th Edition]

NA/EICR/001

53288

Page 2 of 7

## Supply characteristics and earthing arrangements

Earthing Arrangements TN-S  TN-C-S  TT  Other  Please specify: \_\_\_\_\_

Number & type of live conductors a.c.  d.c.  No. of phases 3 No. of wires 4

Nature of Supply Parameters (Note: (†) by enquiry, (‡) by enquiry or by measurement)

Nominal voltage, U<sub>o</sub>(†) 240 v Nominal frequency, f(†) 50 Hz Confirmation of supply polarity

Prospective fault current, I<sub>pf</sub>(‡) 1.47 kA External loop impedance, Z<sub>e</sub>(‡) 0.16 Ω

Supply Protective Device BS 58 361 Type IB Nominal Current Rating 100 A

Other Sources of Supply (as detailed in attached schedule)

## Particulars of installation referred to in this report

Means of Earthing Distributor's facility  Installation earth electrode

Details of Installation earth electrode (where applicable) Type (e.g. rod(s), tape etc) N/A

Location N/A Electrode resistance to earth N/A Ω

Main Protective Conductors	Material	Csa (mm <sup>2</sup> )	Verified	Csa (mm <sup>2</sup> )	Verified
Earthing Conductor	COPPER	16	<input checked="" type="checkbox"/>	Water 10	<input checked="" type="checkbox"/>
Protective Bonding Conductor	COPPER	16	<input checked="" type="checkbox"/>	Gas 10	<input checked="" type="checkbox"/>
Other				Oil	<input checked="" type="checkbox"/>

## Main Switch / Switch-Fuse/ Circuit Breaker / RCD

Location MAINS ROOM BS (EN) 60947-3 No. of Poles 4

Current rating 125 A Fuse/device rating or setting / A Voltage rating 215 V

If RCD main switch: Rated residual operating current I<sub>Δn</sub> = / mA Rated time delay / ms (at I<sub>Δn</sub>)

Measured operating time at I<sub>Δn</sub> = / ms

## Observations

Referring to the attached schedule of inspection and test results, and subject to the limitations at Section D.

No remedial work required OR  The following observations are made

## Explanation of codes

- C1. Danger present. Risk of injury. Immediate remedial action required.
- C2. Potentially dangerous. Urgent remedial action required.
- C3. Improvement recommended.

Item No.	Observations	Code	Further investigation required yes/no
1	NO COVER ON BOILER PUMP & TIMECLOCK	C2	
2	NO RCD PROTECTION ON GROUND SHOWER	C3	
3	BONDING NEEDS UPGRADING TO 16mm <sup>2</sup>	C3	
4	COMMUNAL SOCKETS BUNDLED TOGETHER	C3	
5	GROUND FLOOR SHOWER TERMINALS CHARGED	C2	

One of the above codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

Note: For additional report pages use the continuation report form with the relevant serial number and page numbers detailed on each page.

Immediate remedial work recommended for items

Urgent remedial work recommended for items 1, 5

Improvement(s) recommended for items 2, 3, 4

# NAPIT **Electrical Installation** Condition Report

## Guidance for recipients

This report is an important and valuable document which should be retained for future reference.

1. The purpose of this condition report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
2. The person ordering the Report should have received the original Report and the inspector should have retained a duplicate.
3. The original Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner /occupier with details of the condition of the electrical installation at the time the Report was issued.
4. Where the installation incorporates residual current devices (RCDs) there should be a notice at or near the devices stating that they should be tested quarterly. **For safety reasons it is important that these instructions are followed.**
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as C1 ("Danger Present"), **the safety of those using the installation is at risk**, and it is recommended that a competent person undertakes the necessary remedial work immediately.
8. For items classified in Section K as C2 ("Potentially Dangerous"), **the safety of those using the installation may be at risk** and it is recommended that a competent person undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section K that an observation requires further investigation the inspection has revealed an apparent deficiency which could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a competent person. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit / distribution board.





# NAPIT Electrical Test Schedule Continuation Sheet

Requirements for Electrical Installations - BS 7671:2008 Incorporating Amendment No.1,2011  
[IET Wiring Regulations 17th Edition]

This sheet forms part of Condition Report Number\*/Certificate Number\*  
NA/EC/EICR - - - - - 5 3 2 8 8  
\*Delete as applicable  
Page 4 of 7

Please complete all the unshaded areas.

Circuit No and phase	Circuit designation	Type of wiring	Ref. method	No of points served	Circuit conductors			Overcurrent protective devices				RCD operating current I <sub>Δn</sub> (mA)	BS7671 Max. permitted value Z <sub>s</sub> Other MAX	Circuit impedance Z <sub>c</sub>			Insulation resistance (Record lower reading)		RCD testing		Test Button operation (✓)		
					Live (mm <sup>2</sup> )	CPC (mm <sup>2</sup> )	Maximum disconnection time (BS 7671)	BS EN Number	Type	Rating (A)	pic (kA)			r <sub>1</sub>	r <sub>n</sub>	r <sub>2</sub>	All circuits to be completed using R1 R2 or R2, not both	Live / Live (MΩ)	Live / Earth (MΩ)	Polarity (✓)		Maximum measured Z <sub>s</sub> (Ω)	at 1 <sub>Δn</sub> ms
13	FIRE ALARM	A	D	1	2.5	1.5	5	60598	B	6	6	7.61	-	-	-	X 0.19	-	7200	7200	V 0.35	-	-	-
14	BOILER	A	C	1	2.5	1.5	5	60598	B	16	6	2.55	-	-	-	X 0.11	-	7200	7200	V 0.26	-	-	-
15	COMMON LIGHTS	A	D	21	1.0	1.0	5	60598	B	6	6	7.67	-	-	-	X 0.71	-	7200	7200	V 0.48	-	-	-
16	OUTSIDE LIGHTS	A	D	21	1.5	1.0	5	60598	B	6	6	7.67	-	-	-	X 0.86	-	7200	7200	V 1.02	-	-	-
17	GROUND BORN WHELER	A	D	1	2.5	1.5	5	60598	B	16	6	2.58	-	-	-	X 0.47	-	7200	7200	V 0.64	-	-	-
18	GROUND BORN SWOWER	A	D	1	10.0	6.0	5	60598	B	40	6	1.15	-	-	-	X 0.16	-	7200	7200	V 0.29	-	-	-
Room 1																							
1	LIGHTS	A	D	1	1.0	1.0	5	60598	B	6	6	7.61	-	-	-	X 0.26	-	7200	7200	V 0.38	28	15	✓
2	SOCKETS	A	D	5	2.5	1.5	5	60598	B	32	6	1.44	0.41	0.41	0.75	✓ 0.28	-	7200	7200	✓ 0.51	28	15	✓
3																							
Room 2																							
1	LIGHTS (Circuit 3)	A	D	4	1.5	1.0	4	60598	B	10	6	4.60	-	-	-	X 0.95	-	7200	7200	✓ 0.91	41	23	✓
2	SOCKETS (Circuit 1)	A	C	3	2.5	1.5	4	60598	B	20	6	2.30	-	-	-	X 0.41	-	7200	7200	✓ 0.62	41	23	✓
3	SOCKETS (Circuit 8)	A	C	3	2.5	1.5	4	60598	B	32	6	1.44	0.13	0.14	0.23	✓ 0.08	-	7200	7200	✓ 0.55	39	19	✓

Details of circuits and/or installed equipment vulnerable to damage when testing

NONE

See attached sheets page(s) of

Tested by: Name (capital letters) J WHITTLES

Signature

Date(s) 30 / 4 / 14



# NAPIT Electrical Test Continuation Sheet

Requirements for Electrical Installations - BS 7671 (IEE Wiring Regulations 17th Edition).

Can be used for new installations, additions or alterations.

This sheet is for additional circuits on a fuseboard which exceed the number on the normal test sheet.

Please complete all the unshaded areas.

This sheet forms part of Inspection Report Number\*/Certificate Number\*

NA/EC/PIR - - - - - 5 3 2 8 5  
 \*Delete as applicable  
 Page 5 of 7

## CIRCUIT DETAILS

Circuit No and phase	Circuit designation	Type of wiring	Ref method	No. of points served	Circuit conductors			Maximum disconnection time (BS 7671)	Overcurrent protective devices			RCD operating current (mA)	BS7671 Max. allowed fault current (A) Other: MAX	Circuit impedance (Ω)			All circuits to be completed using R1+R2 or R2 not both R1+R2	Insulation resistance (Record lower reading)			Maximum measured $Z_s$ (Ω)	Date of test (Live)	at 1m	at 5m						
					Live (mm <sup>2</sup> )	CPC (mm <sup>2</sup> )	CSA		BS EN Number	Type	Rating (A)			Short circuit capacity (kA)	$Z_1$	$Z_2$		$Z_n$	Date	Live / Live					Live / Earth	Polarity (✓)				
Room 3																														
1	SOCKETS	C	C	5	2.5	1.5	1.5	4	60848	B	32	6	30	1.44	0.39	0.57	0.73	✓	0.28	—	11	1200	1200	1200	✓	0.68	28	18	✓	
2	LIGHTS	C	C	1	1.0	1.0	1.0	4	60848	B	6	6	30	7.67	—	—	—	✗	0.68	—	11	1200	1200	1200	✓	1.03	28	18	✓	
3	SPACE																													
Room 4																														
1	LOW VOLT SOCKETS (CIRCUIT 3)	C	C	2	2.5	1.5	1.5	4	60848	B	20	6	30	2.35	—	—	—	✗	0.27	—	11	1200	1200	1200	✓	6.68	28	23	✓	
2	SOCKETS (CIRCUIT 4)	C	C	2	2.5	1.5	1.5	4	60848	B	32	6	30	1.44	0.20	0.19	0.45	✓	0.13	—	11	1200	1200	1200	✓	0.56	28	23	✓	
3	LIGHTS	C	C	1	1.0	1.0	1.0	4	60848	B	10	6	30	4.60	—	—	—	✗	0.57	—	11	1200	1200	1200	✓	0.81	28	23	✓	
4	COOKER	C	C	1	2.5	1.5	1.5	4	60848	B	20	6	30	2.30	—	—	—	✗	0.37	—	11	1200	1200	1200	✓	0.65	28	23	✓	
Room 5/6																														
1	LIGHTS	C	C	2	1.0	1.0	1.0	4	60848	B	6	6	30	7.67	—	—	—	✗	0.32	—	11	1200	1200	1200	✓	0.81	35	15	✓	
2	SOCKETS	C	C	1	1.0	1.0	1.0	4	60848	B	32	6	30	1.44	0.25	0.26	0.72	✓	0.12	—	11	1200	1200	1200	✓	0.57	35	15	✓	
3	SPACE																													

Wiring Types: 1 PVC/PVC 2 Single insulated in conduit or trunking 3 Mineral Insulated 4 Xipe/Swa 5 BS-7629-1 (FP200) 6 Other

Comments on installation

NOTE

Tested by: Name (capital letters)

J WIRTLES

Signature

Position

See attached sheets page(s)

of

Date(s)

30/4/14







# NAPIT Electrical Test Schedule Continuation Sheet

Requirements for Electrical Installations - BS 7671:2008 incorporating Amendment No.1,2011  
 [IET Wiring Regulations 17th Edition]

This sheet forms part of Condition Report Number\*/Certificate Number\*  
 NA/EC/EICR - - - - - S 3 2 8 8  
 \*Delete as applicable  
 Page 7 of 7

Please complete all the unshaded areas.

Circuit No. and phase	Circuit designation	Type of wiring	Ref. method	No. of points served	Circuit conductors			Overcurrent protective devices			RCD operating current I <sub>Δn</sub> (mA)	BS7671 permitted value Z <sub>s</sub> Other (Ω)	Circuit impedance (Ω)					Insulation resistance (Record lower reading)			RCD testing		
					Live (mm <sup>2</sup> )	CPC (mm <sup>2</sup> )	Maximum disconnection time (BS 7671) (s)	BS EN Number	Type No.	Rating (A)			Rating (kA)	plc	t <sub>1</sub>	t <sub>n</sub>	t <sub>2</sub>	All circuits to be completed using R1+R2 or R2 not both	Live / Live (MΩ)	Live / Earth (MΩ)	Polarity (✓)	Maximum measured Z <sub>s</sub> (Ω)	at 1s
Room 11																							
1	COOKER (CIRCUIT 3)	A1/K	1	2.5	1.5	0.4	60598	B	20	6	30	2.30	-	-	-	X 0.19	-	+200	200	✓0.52	35	19	✓
2	LIGHTS (CIRCUIT 5)	A1/K	1	1.5	1.0	0.4	60598	B	6	6	30	7.67	-	-	-	X 0.34	-	+200	200	✓0.73	24	13	✓
3	SOCKETS (CIRCUIT 11)	A1/K	6	2.5	1.5	0.4	60598	B	32	6	30	1.44	0.44	0.45	0.65	✓0.19	-	+200	200	✓0.52	24	13	✓
Room 12																							
1	COOKER (CIRCUIT 4)	A1/K	1	2.5	1.5	0.4	60598	B	20	6	30	2.30	-	-	-	X 0.19	-	+200	200	✓0.52	35	18	✓
2	LIGHTS (CIRCUIT 5)	A1/K	1	1.5	1.0	0.4	60598	B	6	6	30	7.67	-	-	-	X 0.22	-	+200	200	✓0.57	35	18	✓
3	SOCKETS (CIRCUIT 11)	A1/K	6	2.5	1.5	0.4	60598	B	32	6	30	1.44	0.26	0.25	0.47	✓0.19	-	+200	200	✓0.57	24	12	✓
Room 14																							
1	NO BOARD																						
2	NO BOARD																						
3	NO BOARD																						
D.B. 2																							
1	SHOWER TOP FLOOR	A1/K	1	6.0	2.5	0.4	60598	B	40	6	30	1.44	-	-	-	X 0.19	-	+200	200	✓0.56	36	22	✓
2	SHOWER GROUND	A1/K	1	6.0	2.5	0.4	60598	B	40	6	30	1.44	-	-	-	X 0.27	-	+200	200	✓0.63	36	22	✓
3	COMMON SOCKETS	A1/K	3	2.5	1.5	0.4	60598	B	16	6	30	2.55	-	-	-	X 0.26	-	+200	200	✓0.50	30	22	✓

Details of circuits and/or installed equipment vulnerable to damage when testing

NONE

See attached sheets page(s) of

Tested by: Name (capital letters) **J WHITTLES**  
 Position

Signature

Date(s) **30 / 4 / 14**

**J Whittles**



# NAPIT Electrical Test Schedule Continuation Sheet

Requirements for Electrical Installations - BS 7671:2008 incorporating Amendment No.1,2011  
[IET Wiring Regulations 17th Edition]

Please complete all the unshaded areas.

This sheet forms part of Condition Report Number\*/Certificate Number\*

NA/EC/EICR - - - - - 5 3 2 8 8  
\*Delete as applicable  
Page 7 of 7

## CIRCUIT DETAILS

Circuit No and phase	Circuit designation	Type of wiring	Ref. method	No. of points served	Circuit conductors			Overcurrent protective devices			RCD permitted value Z <sub>s</sub> Other	Circuit impedance (Z)			Insulation resistance (Record lower reading)			RCD testing						
					Live (mm <sup>2</sup> )	CPC (mm <sup>2</sup> )	Maximum disconnection time (BS 7671) (s)	ESSEN Number	Type NO	Rating (A)		Rating (kA)	Operating current I <sub>Δn</sub> (mA)	BS7671 permitted value Z <sub>s</sub> Other	Ring final circuits only (measured end to end)	R <sub>1</sub>	R <sub>2</sub>	R <sub>1</sub> +R <sub>2</sub>	Live / Live (MΩ)	Live / Earth (MΩ)	Polarity (✓)	Maximum measured Z <sub>s</sub> (Ω)	at I <sub>Δn</sub> ms	at 5 I <sub>Δn</sub> ms
<b>Room 11</b>																								
1	COOPER (CIRCUIT 3)	A1/K	1	2.5	1.5	.4	60548	B	20	6	30	2.30	-	-	-	X 0.19	-	+200	200	✓0.56	36	22	✓	
2	LIGHTS (CIRCUIT 5)	A1/K	1	1.5	1.0	.4	60548	B	6	6	30	7.67	-	-	-	X 0.34	-	+200	200	✓0.73	24	13	✓	
3	SOCKETS (CIRCUIT 11)	A1/K	6	2.5	1.5	.4	60548	B	32	6	30	1.44	0.44	0.45	0.65	✓0.19	-	+200	200	✓0.52	24	13	✓	
<b>Room 12</b>																								
1	COOPER (CIRCUIT 4)	A1/K	1	2.5	1.5	.4	60548	B	20	6	30	2.30	-	-	-	X 0.19	-	+200	200	✓0.52	36	18	✓	
2	LIGHTS (CIRCUIT 5)	A1/K	1	1.5	1.0	.4	60548	B	6	6	30	7.67	-	-	-	X 0.22	-	+200	200	✓0.57	36	18	✓	
3	SOCKETS (CIRCUIT 11)	A1/K	6	2.5	1.5	.4	60548	B	32	6	30	1.44	0.26	0.25	0.47	✓0.19	-	+200	200	✓0.57	24	12	✓	
<b>Room 14</b>																								
1	NO BOARD																							
2	NO BOARD																							
3	NO BOARD																							
<b>D.B. 2</b>																								
1	SHOWER TPO FLOOR	A1/K	1	6.0	2.5	.4	60548	B	40	6	30	1.44	-	-	-	X 0.19	-	+200	200	✓0.56	36	22	✓	
2	SHOWER GROUND	A1/K	1	6.0	2.5	.4	60548	B	40	6	30	1.44	-	-	-	X 0.21	-	+200	200	✓0.63	36	22	✓	
3	COMMON SOCKETS	A1/K	3	2.5	1.5	.4	60548	B	16	6	30	2.30	-	-	-	X 0.26	-	+200	200	✓0.50	36	22	✓	

## TEST RESULTS

Details of circuits and/or installed equipment vulnerable to damage when testing

NONE

See attached sheets page(s) of

Tested by: Name (capital letters)

J WHITTLES

Signature

Position

Date(s) 30 / 4 / 14

do today.

# Stephen Moorhouse Electrician

68A Handel Street, Golcar, Huddersfield HD7 4AE.  
01484-640525 or 07720204192  
Email moorhousestar@sky.com

18/8/16

Mr. J. Leindley,  
65 Woodhouse Hill,  
Fartown,  
Huddersfield.

## INVOICE

Dear Sir,

Electrical work carried out today.

- (a) Checked main earthing from Y.E. supply to two consumer units in cellar area. Both 16mm<sup>2</sup> earthing - no action required.
- (b) The supply for ground floor shown moved from 3 phase Consumer Unit (non-RCD) to smaller 30ma RCD protected consumer unit with a new 40amp MCB. RAR boxes suitably marked.
- (c) Checked socket on first floor landing - no fault found - loop reading 0.4ohms, Satisfactory.

Materials	£15
Labour	£85
Total	<u>£100</u>

Yours faithfully  
S Moorhouse

City & Guilds 2382 (17<sup>th</sup> Edition Wiring Regs)  
City & Guilds 2391 (Inspection & Testing)  
YE Recognised Contractor 0706  
YE Permitted Contractor 0618