

**Synergy Heating Services Ltd**  
Stay safe with Synergy

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

Company / Installer		Job Address		Customer / Landlord	
Engineer	Mark Kneath	Name		Name	Mr Jez Fage
Company	Synergy Heating Services Ltd	Address	14	Company	
Address	13		Marlborough Rd	Address	43
	Morgans Terrace		Brynmill		Swansea Road
	Briton Ferry		Swansea		
	Neath	Post Code	SA2 0AW	Post Code	Swansea
Post Code	SA11 2SY	Tel. No		Tel. No	SA5 7JA
Tel No.	07853260650				
Gas Safe Reg	519419				
ID Card No.	4618885				

Appliance Details										Inspection Details											
1	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Utility Room	Boiler	Viessmann	Vitodens 050	BF	Yes	Yes	19	28	0.0006	63	9.2	NA	NA	NA	Yes	Yes	Yes	Pass	Yes	Yes
2																					
3																					
4																					
5																					
6																					

Defects / Identified					Labels and Warning Notice Issued					CO Alarm(s)			Smoke Alarm(s)		
1									No			CO Alarm(s) fitted	Yes	Smoke Alarm(s) fitted	Yes
2												CO Alarm(s) tested and Satisfactory	Pass	Smoke Alarm(s) tested and Satisfactory	Pass
3															
4															
5															
6															

Emergency Control Accessible <input checked="" type="checkbox"/> Yes	Gas Tightness Satisfactory <input checked="" type="checkbox"/> Yes	<b>Comments</b>     
Gas Installation Pipework Visual Inspection Satisfactory <input checked="" type="checkbox"/> Yes		
Number of Appliances Tested <input type="text" value="1"/>	Equipotential Bonding <input checked="" type="checkbox"/> Yes	
NEXT INSPECTION DUE ON OR BEFORE <input type="text" value="30-Aug-2020"/>		

Signatures		Date	
Issued by: Signed		Received Signed by:	<input type="text"/>
Print Name	<input type="text" value="Mark Kneath"/>	Print Name	<input type="text"/>
		Date	<input type="text" value="29-Jul-2019"/>