

ELECTRICAL INSTALLATION CONDITION REPORT

Contractor's Reference Number

CRN/

Issued in accordance with *British Standard 7671 - Requirements for Electrical Installations* by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

A. DETAILS OF THE CLIENT

Client: MR, J FAGE

Address: 43 LLANGYFELACH ROAD
SWANSEA

Postcode: SA5 7JA

B. PURPOSE OF THE REPORT

This report must be used only for reporting on the condition of an existing installation.

Purpose for which this report is required: LETTING PURPOSES, INSURANCE, LOCAL AUTHORITY

Date(s) on which inspection and testing were carried out: 19/3/19

C. DETAILS OF THE INSTALLATION

Occupier: TENANTS

Address: 14 MARLBOROUGH ROAD
BRYNMILL, SWANSEA

Postcode: SA2 0EA

Estimated age of the electrical installation: 21 years Description of premises: domestic, commercial, industrial, other (Please state) COMMERCIAL Evidence of alterations or additions If yes, estimated age 10 years

Date of previous inspection: 6/9/16

Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No: _____

Records of installation available: _____

Records held by: _____

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:

COMPLETE INSTALLATION

Agreed limitations including the reasons, if any, on the inspection and testing:

CABLES BORED IN FLOORS & WALLS.

Agreed with: CLIENT

Operational limitations including the reasons (see page No. _____)

NONE

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):

INSTALLATION COMPLYS WITH B.S. 7671

Summary of the condition of the installation continued on additional pages? No Yes Specify page No(s): _____

Overall assessment of the installation: **SATISFACTORY** / ~~UNSATISFACTORY~~*

(Delete as appropriate)

* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (FI) is required

ELECTRICAL INSTALLATION CONDITION REPORT

Original (To the person ordering the work)

H. SCHEDULES AND ADDITIONAL PAGES

Inspection Schedule: Page(s) No 4, 5, 6

Additional pages, including additional source(s) data sheets:

Page No(s)

NONE

Schedule of Circuit Details for the Installation: Page No(s) 7 ✓

Schedule of Test Results for the Installation: Page No(s) 8 ✓

The pages identified are an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

ONE YEAR

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or FI (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading title: GARY EDWARDS (A.I. ELECTRICS)

Address: 103 DOLAU FAN ROAD
BURY PORT
CARMARTHENSIRE

Telephone number: 07891471260

Email address:



Enrolment number: (Essential information)

0 2 4 6 5 0

Branch number: (if applicable)

N A

Postcode: SA16 0RP

K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Characteristics of primary supply overcurrent protective device(s)

System type(s)	Number and type of live conductors			Nature of supply parameters			Characteristics of primary supply overcurrent protective device(s)	
	a.c.		d.c.	Nominal voltage(s):	V	$U_0^{(1)}$	BS(EN)	
TN-S ✓	✓			246		230	136/	
TN-CS	1-phase (2-wire) ✓	1-phase (3-wire)	2-pole	Nominal frequency, $f^{(1)}$	Hz	Notes:	Type	
				50		(1) by enquiry	2	
TN-C	2-phase (3-wire)		3-pole	Prospective fault current, $I_{pf}^{(2)(3)}$	kA	(2) by enquiry or by measurement	Rated current	60 A
TT	3-phase (3-wire)	3-phase (4-wire)	other	External earth fault loop impedance, $Z_e^{(3)(4)}$	Ω	(3) where more than one supply, record the higher or highest values	Short-circuit capacity	16 kA
IT	Other	Please state		Number of sources		(4) by measurement	Confirmation of supply polarity	✓(✓)

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of earthing		Details of installation earth electrode (where applicable)					
Distributor's facility: ✓	Type: (eg rod(s), tapes) etc) x	Location: x					
Installation earth electrode: x	Electrode resistance, R_A : x	(Ω) Method of measurement: x					
Main Switch/Switch-Fuse/Circuit-Breaker/ RCD			Earthing and protective bonding conductors				
Type: BS(EN)	60348/3	Voltage rating	240	V	Earthing conductor	Main protective bonding conductors	Bonding of extraneous-conductive-parts (✓)
No of poles	2	Rated current, I_n	100	A	Conductor material	COPPER	Water installation pipes ✓ Lightning protection x
Primary supply conductors: material	COPPER	RCD operating current, $I_{\Delta n}$ *	30	mA	Conductor csa	10 mm ²	Oil installation pipes x Structural steel x
Primary supply conductors: csa	16 mm ²	Rated time delay*	29	ms	Connection/continuity verified	✓(✓)	Gas installation pipes ✓
		RCD operating time (at $I_{\Delta n}$)*	16	ms			Other

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

ELECTRICAL INSTALLATION CONDITION REPORT

INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

Item	Description	Outcome*	Location reference
1.0	Condition/adequacy of distributor's/supply intake equipment†		
1.1	Service cable	✓	Middle Room
1.2	Service head	✓	✓
1.3	Distributor's earthing arrangement(s)	✓	✓
1.4	Meter tails – Distributor/ Consumer	✓	✓
1.5	Metering equipment	✓	✓
1.6	Means of main isolation (where present)	✓	✓
2.0	Presence of adequate arrangements for parallel or switched alternative sources		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	✓	✓
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	✓	✓
3.0	Automatic disconnection of supply		
3.1	Main earthing and bonding arrangements	✓	✓
	• Presence and condition of distributor's earthing arrangement	✓	✓
	• Presence and condition of earth electrode arrangement	✓	✓
	• Adequacy of earthing conductor size	✓	✓
	• Adequacy of earthing conductor connections	✓	✓
	• Accessibility of earthing conductor connections	✓	✓
	• Adequacy of main protective bonding conductor size(s)	✓	✓
	• Adequacy of main protective bonding conductor connections	✓	✓
	• Accessibility of main protective bonding connections	✓	✓
	• Accessibility and condition of other protective bonding connections	✓	✓
	• Provision of earthing/bonding labels at all appropriate locations	✓	✓
3.2	FELV		
	• Source providing at least simple separation	✓	✓
	• Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises	✓	✓
3.3	Reduced low voltage		
	• Adequacy of source	✓	✓
	• Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises	✓	✓
4.0	Other methods of protection (where the methods of protection listed below are employed, details should be provided on separate sheets)		
4.1	Double insulation	✓	✓
4.2	Reinforced insulation	✓	✓
4.3	Use of obstacles	✓	✓
4.4	Placing out of reach	✓	✓
4.5	Non-conducting location	✓	✓
4.6	Earth-free local equipotential bonding	✓	✓
4.7	Electrical separation for more than one item of equipment	✓	✓
5.0	Distribution equipment		
5.1	Adequacy of working space/accessibility of equipment	✓	✓
5.2	Security of fixing	✓	✓
5.3	Condition of insulation of live parts	✓	✓
5.4	Adequacy/security of barriers	✓	✓
5.5	Condition of enclosure(s) in terms of IP rating	✓	✓
5.6	Condition of enclosure(s) in terms of fire rating	✓	✓
5.7	Enclosure not damaged/deteriorated so as to impair safety	✓	✓
5.8	Presence of main switch(es), linked where required	✓	✓
5.9	Operation of main switch(es) (functional check)	✓	✓
5.10	Correct identification of circuit protective devices	✓	✓
5.11	Adequacy of protective devices for prospective fault current	✓	✓
5.12	RCD(s) provided for fault protection – includes RCBOs	✓	✓
5.13	RCD(s) provided for additional protection – includes RCBOs	✓	✓

* All Outcome boxes must be completed.
 ✓ indicates Acceptable condition
 'LIM' indicates a Limitation
 'N/A' indicates Not applicable

Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

† Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.

ELECTRICAL INSTALLATION CONDITION REPORT

INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

Item	Description	Outcome*	Location reference
7.0	Isolation and switching		
7.1	Isolators		
	• presence and condition of appropriate devices	✓	Hare
	• acceptable location (state if local or remote)	✓	u
	• capable of being secured in the OFF position	✓	u
	• correct operation verified	✓	u
	• clearly identified by position and/or durable marking(s)	✓	u
	• Warning label posted in situations where live parts cannot be isolated by the operation of a single device	✓	u
7.2	Switching off for mechanical maintenance		
	• presence and condition of appropriate devices	✓	u
	• acceptable location	✓	u
	• capable of being secured in the OFF position	✓	u
	• correct operation verified	✓	u
	• clearly identified by position and/or durable marking(s)	✓	u
7.3	Emergency switching/stopping		
	• presence and condition of appropriate devices	✓	u
	• readily accessible for operation where danger might occur	✓	u
	• correct operation verified	✓	u
	• clearly identified by position and/or durable marking(s)	✓	u
7.4	Functional switching		
	• presence and condition of appropriate devices	✓	u
	• correct operation verified	✓	u
8.0	Current-using equipment (permanently connected)		
8.1	Condition of equipment in terms of IP rating	✓	u
8.2	Equipment does not constitute a fire hazard	✓	u
8.3	Enclosure not damaged/deteriorated so as to impair safety	✓	u
8.4	Suitability for the environment and external influences	✓	u
8.5	Security of fixing	✓	u
8.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire (indicate extent of sampling in Section D of report)	✓	u
8.7	Recessed luminaires (e.g. downlighters)		
	• correct type of lamps fitted	✓	u
	• installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar	✓	u
	• no signs of overheating to surrounding building fabric	✓	u
	• no signs of overheating to conductors/terminations	✓	u
9.0	Location(s) containing a bath or shower		
9.1	Additional protection by RCD not exceeding 30 mA		
	• for low voltage circuits serving the location	✓	u
	• for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	✓	u
9.2	Where used as a protective measure, requirements for SELV or PELV are met	✓	u
9.3	Shaver sockets comply with BS EN 61558-2-5 or BS 3535	✓	u
9.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓	u
9.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	✓	u
9.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓	u
9.7	Suitability of equipment for installation in a particular zone	✓	u
9.8	Suitability of current-using equipment for a particular position within the location	✓	u
10.0	Other special installations or locations		
	List special locations present, if any. List the results of particular inspections applied (a separate page is required for each location).		
		X	—

Original (To the person ordering the work)

* All Outcome boxes must be completed.
 ✓ indicates Acceptable condition
 LIM indicates a Limitation
 N/A indicates Not applicable

Unacceptable condition state C1 or C2
 Improvement recommended state C3
 Further investigation required without delay state FI
 (to determine whether danger or potential danger exists)

Outcome
 Provide additional comment where appropriate on attached numbered sheets. C1, C2, C3 and FI coded items to be recorded in Section F of the report.

SCHEDULE OF CIRCUIT DETAILS FOR THE PRIMARY DISTRIBUTION BOARD

TO BE COMPLETED IN EVERY CASE	TO BE COMPLETED ONLY IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION*			
Location of distribution board: MIDDLE ROOM	Supply to distribution board is from:	No of phases:	Nominal voltage:	V
Distribution board designation: CUPBOARD	Overcurrent protective device for the distribution circuit:	Associated RCD (if any) : BS (EN)		
1	Type: BS (EN)	Rating: A	RCD No of poles:	I _{Δn} mA

CIRCUIT DETAILS

Circuit number and line	Circuit designation	Type of wiring (see code below)	Reference method	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time permitted by BS 7671 (s)	BS (EN)			Operating current, I _{Δn} (mA)	Maximum Z _s permitted by BS 7671 (Ω)	
								MCB	Type	Rating (A)			Short-circuit capacity (kA)
1	COOKER	1	101	1	6.0	2.5	0.4	60898	n	32	6	30	1.50
2	SHOWER	1	n	1	6.0	2.5	n	n	n	32	n	4	1.50
3	POWER RING MAIN	1	1	22	2.5	1.5	n	n	n	32	n	4	1.50
4	POWER RING MAIN	1	n	19	2.5	1.5	n	n	n	32	n	4	1.50
5	LIGHTING UPSTAIRS/ALARMS	1	n	10	1.0	1.0	n	n	n	6	n	4	8
6	LIGHTING UPSTAIRS	1	n	7	1.0	1.0	n	n	n	6	n	4	8
7	LIGHTING DOWNSTAIRS	1	n	8	1.0	1.0	n	n	n	6	n	4	8

* In such cases, details of the distribution (sub-main) circuit(s), together with the test results for the circuit(s), must also be provided on continuation schedules.

↑ See Table 4A2 of Appendix 4 of BS 7671

CODES FOR TYPE OF WIRING								
A	B	C	D	E	F	G	H	O (Other - please state)
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic /SWA cables	Thermosetting /SWA cables	Mineral-insulated cables	

