

Gas Safety Record

This Gas Safety Record was completed on 21 Nov 2018 by Darren Plant, 211124.
 Number of appliances: 2
 Your next Gas Safety Check is due on 21 Nov 2019

Serial No: 000072

Registered Business
 Diamond Heating and Plumbing LTD
 Address: 85d Richmond Wood Road, Bournemouth
 code: BH8 9DQ
 Gas Safe No: 211124
 Phone: 07817742645

Job Address
 Name:
 Address: 1 Salmews, 2a Luther Rd, Winton
 Postcode:

Client Details
 Client Name: Paul Lawton
 Address: 18 Fulmar Rd, Mudeford
 Postcode:

Phone:

Appliance type	Make	Model	Landlord's appliance	Appliance inspected	Appliance serviced	Appliance safe to use
Boiler	Worcester	25si	Yes	Yes	No	Yes
Hob	Electrolux		Yes	Yes	No	Yes

Operating pressure (Mbar)	Heat input (kW/h or btu/h)	Initial combustion analyser reading	Final combustion analyser reading	Safety device correct operation	Ventilation provision satisfactory	Visual condition of chimney/termination satisfactory	Flue type	Spillage test	Smoke pellet flue flow test	Flue visual condition	Flue performance checks	Approved CO alarm fitted	Is CO alarm in date	Testing of CO alarm satisfactory
19 Mbar	25 kW/h	0.0005		Yes	Yes	Yes	RS	n/a	n/a	Pass	n/a	Yes	Yes	Yes
19 Mbar				n/a	Yes	n/a	FL	n/a	n/a	n/a	n/a	Yes	Yes	Yes

Actions taken	Warning Notice

Issued by: 

Gas operative: Darren Plant
 21 Nov 2018
 Gas Safe ID No: 211124

Received by:

21 Nov 2018
Gas User/Client Not Present

Installation	Yes
Installation pipework visual inspection satisfactory	Yes
Agency control valve (ecv) accessible	Yes
Factory gas tightness test	Yes
Active equipotential bonding satisfactory	Yes
Installation Notes:	
Installation Warning Notice Completed	N/A
Critical Cross Bonding Notice Completed	N/A

This record allows results of the required checks defined by the Gas Safety (Installation and Use) Regulations to be recorded. The information recorded does not confirm that the installation was installed by a Registered Installer or that the installation complies with any relevant Building Regulations. Systems were inspected visually and checked for satisfactory evacuation products of combustion, please note a detailed internal inspection of the chimney system has not been carried out. WARNING: Please read and act upon the Warning Notice and/or Electrical Cross Bonding Record if applicable.
 © Copyright Easy Safety Cert Ltd.