

ELECTRICAL INSTALLATION CONDITION REPORT

(Requirements for Electrical Installations – BS 7671
IEE Wiring Regulations)

DETAILS OF THE CLIENT

Name: Mr .d .r .jones.

Address: 68 the highway, Orpington, kent . BR6 9DJ.

PURPOSE FOR WHICH THIS REPORT IS REQUIRED

This report must be used only for reporting on the condition of an existing installation.

Electrical safety report ,for letting of property .

Date(s): 18/11/16

DETAILS OF THE INSTALLATION

Occupier:

Address: 42 COPINGER CLOSE CT2 7DJ

Description of Premises:

Domestic

✓

Commercial

Industrial

Other

Estimated age of the Electrical Installation:

20

Years

Evidence of Alterations or Additions:

YES

If "yes" estimated age:

10

Years

Date of previous Inspection:

14/06/07

Electrical Installation Certificate No: or previous
Periodic Inspection report No:

Records of installation available.

Records held by:

OWNER .

EXTENT OF THE INSTALLATION AND LIMITATIONS OF THE INSPECTION AND TESTING

Extent of the Electrical installation covered by this report:

Lighting , power , cooker and smoke detector circuits .

Agreed Limitations (including the reasons), if any, on the inspection and testing

No acces to roof space . Flushed in cables for power drops and lighting inaccessible .

Operational limitations including the reasons (see page No.)

Some power points not accesable .

This inspection has been carried out in accordance with BS 7671:2008, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in roof spaces and generally within the fabric of the building or under ground have not been inspected.

SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):

GOOD.

If necessary, continue on additional page(s)? No

✓

Yes

Specify page

Overall assessment of the
installation:

SATISFACTORY . (Delete as appropriate)

An "Unsatisfactory" assessment indicates that dangerous and/or potentially dangerous conditions have been identified.

SCHEDULES AND ADDITIONAL PAGES

Schedule of items inspected Page No. 4.5.6.7

Additional pages, including additional source(s) data sheets: Page No(s):

Schedule of Circuit Details for the installation: Page No(s): 8

Schedule of Test Results for the installation: Page No(s): 8

The pages identified here form an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.

NEXT INSPECTION

18/11/2021

We recommend that this installation is further inspected and tested after an interval of not more than 5 years

Provided that any items which have been attributed a Recommendation Code C1 and C2 (require urgent attention) are remedied without delay and as soon as possible respectively. Items which have been attributed a Recommendation Code C3 should be actioned as soon as practicable (see F).

DETAILS OF ELECTRICAL CONTRACTOR

Trading Title: PHILIP DEERE.

Address: 24 CORNWALLIS CIRCLE, WHITSTABLE, KENT.

Postcode: CT5 1 DU.

Telephone number: 07789514523

Fax number: N/A

Registration number

Branch number:

(if applicable)

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Tick boxes and enter details, as appropriate

System Type(s)	Number and Type of Live Conductors		Nature of Supply Parameters			Characteristics of Primary supply Overcurrent Protective Device(s)	
	AC	DC	Nominal Voltage U (1)			BS(EN)	
TN-S			230	V		1361	
TN-C-S	1-phase (2 wire) ✓	1-phase (3 wire)	50	Hz		Type II	
TN-C	2-phase (3 wire)	3-phase (3 wire)	1.63	kA		Rated current	80 A
TT	3-phase (4 wire)	2 pole	External earth fault loop impedance Ze (3/4)	0.14	Ω	Short-circuit capacity	kA
IT	3 pole	other	Number of supplies	1		(3) where more than one supply, the higher or highest values	
	Other (Please state)		NOTES:		1) by enquiry	(4) by measurement	
					2) by enquiry or by measurement		

PARTICULARS OF INSTALLATION AT THE ORIGIN

Tick boxes and enter details, as appropriate

Means of earthing		Details Installation Earth Electrode (where applicable)				Earthing and Protective Bonding Conductors	
Distributor's facility ✓		Type: n/a		Location:	Maximum Demand:		kVA/Amps
Installation earth electrode		(eg rod(s), tape etc)		Method of measurement:	Protective measures against electric Shock:		
# Main Switch or Circuit Breaker		Electrode resistance, RA:	Ω				
Type (BS(EN))	60947-3	Voltage Rating	230	V	Earthing conductor	Conductor csa	16 mm ²
No of Poles	2	Rated current I n	100	A	Conductor material	copper	Continuity check ✓ (✓)
Supply conductors: material	copper	RCD operating current I n	30	mA	Bonding of extraneous-conductive-parts (✓)		
Supply conductors: csa	16 mm ²	RCD operating time (at I n)	30	ms	Gas service	✓	Lighting
					Water service	✓	Structural steel
					Oil service		Other service(s)

INSPECTION SCHEDULE FOR DISTRIBUTION BOARDS AND CIRCUITS

Item	Description	Outcome*	Location reference
1.0 Condition/adequacy of distributor's supply intake equipment			
1.1	Service cable	√	
1.2	Service cut-out/fuse(s)	√	
1.3	Meter tails - distributor	√	
1.4	Meter tails - consumer	√	
1.5	Metering equipment	√	
1.6	Means of main isolation (where present)	n/a	
2.0 Presence of adequate arrangements for parallel or switched alternative sources			
		n/a	
3.0 Automatic disconnection of supply			
3.1 Main earthing and bonding arrangements			
* Presence and condition of distributor's earthing arrangement		√	
* Presence and condition of earth electrode arrangement		n/a	
* Adequacy of earthing conductor size		n/a	
* Adequacy of earthing conductor connections		√	
* Accessibility of earthing conductor connections		√	
* Adequacy of main protective bonding conductor size(s)		√	
* Adequacy of main protective bonding conductor connections		√	
* Accessibility of main protective bonding connections		√	
* Provision of earthing/bonding labels at all appropriate locations		√	
3.2 FELV			
* Source providing at least simple separation		√	
* Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises		n/a	
3.3 Reduced low voltage			
* Adequacy of source		√	
* Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises		n/a	
4.0 Other methods of protection (where the methods of protection listed below are employed, details should be provided on separate sheets)			
4.1	Double insulation	√	
4.2	Reinforced insulation	√	
4.3	Use of obstacles	√	
4.4	Placing out of reach	n/a	
4.5	Non-conducting location	n/a	
4.6	Earth-free local equipotential bonding	n/a	
4.7	Electrical separation for more than one item of equipment	√	
5.0 Distribution equipment			
5.1	Adequacy of working space/accessibility of equipment	√	
5.2	Security of fixing	√	
5.3	Condition of insulation of live parts	√	
5.4	Adequacy/security of barriers	√	
5.5	Condition of enclosure(s) in terms of IP rating	√	
5.6	Condition of enclosure(s) in terms of fire rating	√	
5.7	Enclosure not damaged/deteriorated so as to impair safety	√	
5.8	Presence of main switch(es), linked where required	n/a	

5.9	Operation of main switch(es) (functional check)	✓	
5.10	Correct identification of circuit protective devices	✓	
5.11	Adequacy of protective devices for prospective fault current	✓	
5.12	RCD(s) provided for fault protection – includes RCBOs	✓	
5.13	RCD(s) provided for additional protection – includes RCBOs	✓	
5.14	RCD(s) provided for protection against fire – includes RCBOs	✓	
5.15	Manual operation of circuit-breakers and RCDs to prove disconnection	✓	
5.16	Presence of RCD retest notice at or near equipment where required	✓	
5.17	Presence of diagrams, charts or schedules at or near equipment where required	✓	
5.18	Presence of non-standard (mixed) cable colour warning notice at or near equipment where required	✓	
5.19	Presence of alternative supply arrangement warning notice(s) at or near equipment where required	✓	
5.20	Presence of replacement next inspection recommendation label	✓	
5.21	Presence of other required labelling (specify)		Rcd test label.
5.22	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	✓	
5.23	Protection against mechanical damage where cables enter equipment	✓	
5.24	Protection against electromagnetic effects where cables enter metallic enclosures	✓	
6.0 Distribution/final circuits			
6.1	Identification of conductors	✓	
6.2	Cables correctly supported throughout their length		LIM
6.3	Condition of insulation of live parts	✓	
6.4	Non-sheathed cables protected by enclosure in conduit, duct or trunking		n/a
6.5	Suitability of containment systems for continued use (including flexible conduit)		LIM
6.6	Cables correctly terminated in enclosures (indicate extent of sampling in Section D of report)	✓	
6.7	Examination of cables for signs of unacceptable thermal and mechanical damage/deterioration		LIM
6.8	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓	
6.9	Adequacy of protective devices; type and rated current for fault protection	✓	
6.10	Presence and adequacy of circuit protective conductors	✓	
6.11	Co-ordination between conductors and overload protective devices	✓	
6.12	Cable installation methods/practices appropriate to the type and nature of installation and external influences	✓	
6.13	Cables where exposed to direct sunlight, of a suitable type		n/a
6.14	Concealed cables installed in prescribed zones (see extent and limitations)		LIM
6.15	Concealed cables incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage caused by nails, screws and the like where not in prescribed zones or not protected by 30 mA RCD (see extent and limitations)		LIM
6.16	Provision of additional protection by 30 mA RCD for cables concealed in walls or partitions	✓	
6.17	Provision of additional protection by 30 mA RCD	✓	
	* Where reasonably likely to be used to supply mobile equipment for use outdoors	✓	
	* For all socket-outlets of rating 20 A or less provided for use by ordinary persons	✓	
6.18	Provision of fire barriers, sealing arrangements and protection against thermal effects	✓	
6.19	Band II cables segregated/separated from Band I cables		n/a
6.20	Cables segregated/separated from non-electrical services	✓	
6.21	Termination of cables at enclosures (Identify numbers and locations of items inspected in Section D)	✓	
	* Connections under no undue strain	✓	
	No basic insulation of a conductor visible outside an enclosure	✓	
	Connections of live conductors adequately enclosed	✓	
	Adequacy of connection at point of entry to enclosure (gland, bush or similar)	✓	
6.22	General condition of wiring systems	✓	
6.23	Temperature rating of cable insulation	✓	
6.24	Condition of accessories including socket-outlets, switches and joint boxes	✓	
6.25	Suitability of accessories for external influences	✓	
7.0	Isolation and switching	✓	✓

7.1 Isolations	
* presence and condition of appropriate devices	√
* acceptable location	√
* capable of being secured in the OFF position	√
* correct operation verified	√
* clearly identified by position and/or durable marking(s)	√
* Warning label posted in situations where live parts cannot be isolated by the operation of a single device	
7.2 Switching off for mechanical maintenance	
* presence and condition of appropriate devices	√
* acceptable location	√
* capable of being secured in the OFF position	√
* correct operation verified	√
* clearly identified by position and/or durable marking(s)	√
7.3 Emergency switching/stopping	
* presence and condition of appropriate devices	n/a
* readily accessible for operation where danger might occur	n/a
* correct operation verified	n/a
* clearly identified by position and/or durable marking(s)	n/a
7.4 Functional switching	
* presence and condition of appropriate devices	√
* correct operation verified	√
8.0 Current-using equipment (permanently connected)	
8.1 Condition of equipment in terms of IP rating	√
8.2 Equipment does not constitute a fire hazard	√
8.3 Enclosure not damaged/deteriorated so as to impair safety	√
8.4 Suitability for the environment and external influences	√
8.5 Security of fixing	√
8.6 Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire (Indicate extent of sampling in Section D of report)	√
8.7 Recessed luminaires (e.g. downlighters)	
* correct type of lamps fitted	n/a
* installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar	n/a
* no signs of overheating to surrounding building fabric	n/a
* no signs of overheating to conductors/terminations	n/a
9.0 Location(s) containing a bath or shower	
9.1 Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA	√
9.2 Where used as a protective measure, requirements for SELV or PELV are met	n/a
9.3 Shaver sockets comply with BS EN 61558-2-5 or BS 3535	n/a
9.4 Presence of supplementary bonding conductors unless not required by BS 7671: 2008	n/a
9.5 Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	√
9.6 Suitability of equipment for external influences for installed location in terms of IP rating	√
9.7 Suitability of equipment for installation in a particular zone	√
9.8 Suitability of current-using equipment for a particular position within the location	√
10.0 Other Special Installations or locations	
List special locations present, if any. List the results of particular inspections applied.-- a separate page is required for each location	n/a

* All Boxes must be completed

Unacceptable condition state C1 or C2

Outcome

✓ Indicates Acceptable condition

Improvement recommended state C3

Provide additional comment where appropriate on attached numbered sheets. C1, C2 and C3 coded items to be recorded in section F of the report.

LIM indicates a limitation

Further investigation required state F/I (to determine whether danger or potential danger exists)

N/A indicates Not applicable

SCHEDULE OF ITEMS TESTED

✓	External earth loop impedance, Ze	✓	Basic protection against direct contact by barrier or enclosure provided during erection
n/a	Installation earth electrode resistance Ra	n/a	Insulation of non-conducting floors or walls
✓	Continuity of protective conductors	✓	Polarity
✓	Continuity of ring circuit conductors	✓	Earth fault loop impedance Zs
✓	Insulation resistance between live conductors	n/a	Verification of phase sequence
✓	Insulation resistance between live conductors and earth	✓	Operation of residual current devices
✓	Protection by separation of circuits	✓	Functional testing of assemblies
		✓	Verification of voltage drop

TEST INSTRUMENTS USED

Earth fault loop impedance	Mft1552
Insulation resistance	Mft1552
Continuity	Mft1552
RCD	Mft1552
Other	N/A
Other	N/A

NOTES FOR RECIPIENT

THIS CERTIFICATE IS A VALUABLE DOCUMENT AND SHOULD BE RETAINED FOR FUTURE REFERENCE

This Electrical Installation Condition Report form is intended for the reporting on the condition of an existing electrical installation.

You should have received an original Certificate and the contractor should have retained a duplicate. If you were the person ordering this report, but not the owner of the installation, you should pass this Report, or a full copy of it, immediately to the user.

The original Report is to be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Report will provide the new owner with the details of the condition of the electrical installation at the time the Report was issued.

The 'Extent and Limitations' box should fully identify the extent of the installation covered by this Report and any limitations on the inspection and tests. The contractor should have agreed these aspects with you and any interested parties (Licensing Authority, Insurance Company, Building Society etc) before the inspection was carried out.

The Report will usually contain a list of recommended actions necessary to bring the installation up to the current standard. For items classified as 'requires urgent attention', the safety of those using the installation may be at risk, and it is recommended that a competent person undertake the necessary remedial work without delay.

For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a competent person. The maximum time interval recommended before the next inspection is stated in the Report under "Next Inspection."

CODES FOR TYPES OF WIRING								
A	B	C	D	E	F	G	H	O (other please state)
PVC/PVC CABLES	PVC CABLES IN METALLIC CONDUIT	PVC CABLES IN NON-METALIC CONDUIT	PVC CABLES IN METALIC TRUNKING	PVC CABLES IN NON-METALIC TRUNKING	PVC/SWA CABLES	XLPE/SWA CABLES	MINERAL-INSULATED CABLES	